

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							20-May-17
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT SHUT DOWN
2	NASHIK	1	46	546	425	121	AS PER SYSTEM CONDITION
		67	96	546	425	121	AS PER SYSTEM CONDITION
3	REL DAHANU U1 AND U2	1	44	462	336	126	AS PER SYSTEM CONDITION
		67	96	462	336	126	AS PER SYSTEM CONDITION
4	TPCU-8	1	43	235	187	48	AS PER SYSTEM CONDITION
		67	96	235	187	48	AS PER SYSTEM CONDITION
5	TPC U-5	1	43	473	292	181	AS PER SYSTEM CONDITION
		67	96	473	292	181	AS PER SYSTEM CONDITION
6	RATTANINDIA U1,2,3,4,5	1	23	735	516	219	AS PER SYSTEM CONDITION
		32	42	735	516	219	AS PER SYSTEM CONDITION
		68	85	735	516	219	AS PER SYSTEM CONDITION
7	BHUSWAL U2,3	1	23	179	144	35	AS PER SYSTEM CONDITION UNIT-2 SHUT DOWN
		32	41	179	144	35	AS PER SYSTEM CONDITION UNIT-2 SHUT DOWN
		70	85	179	144	35	AS PER SYSTEM CONDITION UNIT-2 SHUT DOWN
8	KORADI U-5 TO U-7	1	23	X	X	X	KORADI UNIT-7 RUNNING BELOW TECH . MIN UNIT-5 AND UNIT-6 SHUT DOWN
		32	41	X	X	X	KORADI UNIT-7 RUNNING BELOW TECH . MIN UNIT-5 AND UNIT-6 SHUT DOWN
		70	85	X	X	X	KORADI UNIT-7 RUNNING BELOW TECH . MIN UNIT-5 AND UNIT-6 SHUT DOWN
9	DHARIWAL TO MSEB	1	23	150	140	10	AS PER SYSTEM CONDITION
		32	41	150	140	10	AS PER SYSTEM CONDITION
		70	85	150	140	10	AS PER SYSTEM CONDITION
10	VIPL U1 AND U2	1	23	546	382	164	AS PER SYSTEM CONDITION
		32	41	546	382	164	AS PER SYSTEM CONDITION
		70	85	546	382	164	AS PER SYSTEM CONDITION
11	PARLEY U-8	1	6	458	332	126	AS PER SYSTEM CONDITION
		32	41	458	332	126	AS PER SYSTEM CONDITION
		70	85	458	332	126	AS PER SYSTEM CONDITION
12	BHUSWAL U-4 AND U-5	1	6	940	644	296	AS PER SYSTEM CONDITION
		33	36	940	644	296	AS PER SYSTEM CONDITION
		70	85	940	644	296	AS PER SYSTEM CONDITION
13	PARLEY U-6, 7	1	6	458	332	126	AS PER SYSTEM CONDITION
		30	42	458	332	126	AS PER SYSTEM CONDITION
		49	96	458	332	126	AS PER SYSTEM CONDITION
14	KHAPERKHEDE U1 TO U4	1	5	733	572	161	AS PER SYSTEM CONDITION
		70	76	669	572	97	AS PER SYSTEM CONDITION
15	KHAPERKHEDE U-5	1	5	428	335	93	AS PER SYSTEM CONDITION
		70	76	380	335	45	AS PER SYSTEM CONDITION
16	KORADI U8 ,U9,10	1	3	X	X	X	D.C. BELOW TECH MIN
		70	76	X	X	X	D.C. BELOW TECH MIN
17	PARAS U-3 ANDU-4	1	3	230	168	62	UNIT-3 SHUT DOWN , B/D AS PER SYSTEM CONDITION
		70	76	460	332	128	UNIT-3 SYN. AT 5:21HRS. B/D AS PER SYSTEM CONDITION
18	ADANI 440 PPA	1	3	X	X	X	D.C. BELOW TECH MIN
		71	76	X	X	X	D.C. BELOW TECH MIN
19	ADANI U-1(1200MW &125MW PPA)	1	3	X	X	X	D.C. BELOW TECH MIN
		71	76	X	X	X	D.C. BELOW TECH MIN
20	ADANI U-4(1200MW &125MW PPA)	1	3	X	X	X	D.C. BELOW TECH MIN
		71	76	X	X	X	D.C. BELOW TECH MIN
21	ADANI U-4(1200MW &125MW PPA)	1	3	X	X	X	D.C. BELOW TECH MIN
		71	76	X	X	X	D.C. BELOW TECH MIN
22	CHANDRAPUR U3 TO U7	71	76	1188	954	234	UNIT-7 SHUT DOWN., B/D AS PER SYSTEM CONDITION
23	CHANDRAPUR U8 AND U9	71	76	748	658	90	AS PER SYSTEM CONDITUION
24	ADANI UNIT-2	73	76	X	X	X	D.C. BELOW TECH MIN
25	ADANI U-3	73	76	X	X	X	D.C. BELOW TECH MIN
26	JSW U-1	X	X	X	X	X	NO BACK DOWN

NOTE:

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- M.O.D.RATES EFFECTIVE FROM 12TH AF May-17
- # Indicates that back down withdrawn due to Line loading/system constraints.