

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

20-Jun-13

| SR. NO. | GENERATING STN. / STOA | Backing Down Period (in Time Block) | | (In MW) | | Backing Down Quantum (Max in MW /A-B) | REMARK |
|---------|------------------------|-------------------------------------|----|-----------------------|--------------------------------------|---------------------------------------|--------------------------------------------------|
| | | FROM | TO | Declared Capacity (A) | Target Dispatched Schedule (Min) (B) | | |
| 1 | TPC U-6 | 1 | 42 | 483 | 145 | 338 | AS PER MOD |
| | | 43 | 63 | 483 | 325 | 158 | |
| | | 64 | 96 | 483 | 145 | 338 | |
| 2 | GEPL TO TPC | 37 | 37 | 70 | 49 | 21 | AS PER MOD |
| | | 69 | 76 | | | | |
| 3 | NASIK | 1 | 12 | 516 | 425 | 91 | AS PER MOD |
| | | 70 | 75 | 262 | 226 | 36 | AS PER MOD, U 4 TRIPPED |
| | | 87 | 96 | | | | |
| 4 | BRUSANVAL 2,3 | X | X | X | X | X | DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM |
| 5 | TPC U-5 | 7 | 26 | 473 | 292 | 181 | AS PER MOD |
| | | 67 | 70 | 473 | 420 | 53 | DUE TO SYSTEM CONDITION |
| | | 86 | 96 | 473 | 292 | 181 | |
| 6 | TPC U-8 | 7 | 23 | 235 | 172 | 63 | AS PER MOD |
| | | 96 | 96 | 235 | 227 | 8 | |
| 7 | KORADI 5,6,7 | X | X | X | X | X | DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM |
| 8 | REL G | 7 | 22 | 478 | 400 | 78 | DUE TO SYSTEM CONDITION |

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f. 12-June-2013.