

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	JSW U-2,3,4 TO AEML	1	19	300	210	90	AS PER SYSTEM CONDITION
		93	96	300	210	90	AS PER SYSTEM CONDITION
2	DTPS U-1 AND U-2	1	19	455	336	119	AS PER SYSTEM CONDITION
		93	96	455	336	119	AS PER SYSTEM CONDITION
3	TPC U-8	1	19	205	187	18	AS PER SYSTEM CONDITION
4	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
5	VIPL U-1 AND U-2	X	X	X	X	X	UNIT-1 AND UNIT-2 SHUT DOWN
6	TPC U-5	4	20	460	292	168	AS PER SYSTEM CONDITION
7	KORADI U-6 AND U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
8	PARALI U-8	X	X	X	X	X	UNIT SHUT DOWN
9	NASHIK U-3,4,5	5	20	279	244	35	AS PER SYSTEM CONDITION /U-5 UNDER ZERO SCHEDULE
10	PARALI U-6 AND U-7	X	X	X	X	X	UNIT SHUT DOWN
11	RATTANINDIA U-1 TO U-5	6	18	980	688	292	U-2 UNDER ZERO SCHEDULE
12	BHUSAWAL U-4 AND U-5	X	X	X	X	X	NO BACK DOWN
13	CHANDRAPUR U-3 TO U-7	X	X	X	X	X	NO BACK DOWN
14	KORADI U-8 TO U-10	X	X	X	X	X	NO BACK DOWN
15	PARAS U-3 AND U-4	X	X	X	X	X	NO BACK DOWN
16	CHANDRAPUR U-8 AND U-9	X	X	X	X	X	NO BACK DOWN
17	ADANI TIRODA U-1,4,5 (PPA440 MW)	X	X	X	X	X	NO BACK DOWN
18	ADANI TIRODA U-1,4,5 (PPA1200MW,125 MW)	X	X	X	X	X	NO BACK DOWN
19	JSW U-1	X	X	X	X	X	NO BACK DOWN
20	KHAPERKHEDA U-1 TO U-4	X	X	X	X	X	NO BACK DOWN
21	KHAPERKHEDA U-5	X	X	X	X	X	NO BACK DOWN
22	ADANI U-2 & U-3	X	X	X	X	X	NO BACK DOWN

## Note :

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backindown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- MOD RATES REVISED FROM 15:00HRS OF 16TH APRIL2019 AS PER OLD PROCEDURE Stayed Due to Hon'ble APPELLATE TRIBUNAL order in IA No. 593 of 2019 in DFR No.1762 of 2019
- # Indicates that back down withdrawn due to Line loading/system constraints.
- REVISED MOD RATES EFFECTIVE FROM 00:00HRS 12TH AUG 2019