

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	36	506	425	81	AS Per MOD
		37	76				DUE TO SYSTEM CONDITION
		82	96				
3	TPC U-8	1	37	235	172	63	AS Per MOD
		51	57	235	200	35	
4	TPC U-5	1	37	473	292	181	AS Per MOD
5	PARALI-6	1	4	200	166	34	DUE TO SYSTEM CONDITION
		5	22	200	166	34	AS Per MOD
		36	76				DUE TO SYSTEM CONDITION
		82	96				
6	PARALI 3,4,5	1	4	145	138	7	DUE TO SYSTEM CONDITION
		5	22				AS Per MOD
		36	44				DUE TO SYSTEM CONDITION
		45	96	X	X	X	DC REVISED TO BELOW TECHNICAL MINIMUM DUE TO PCQ
7	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	PARALI-7	1	5	200	166	34	DUE TO SYSTEM CONDITION
		6	22				AS Per MOD
		36	76				DUE TO SYSTEM CONDITION
		82	96				
10	REL G	1	8	477	336	141	DUE TO SYSTEM CONDITION
		9	21	478	400	78	AS Per MOD
		48	55				DUE TO SYSTEM CONDITION
11	CHANDRAPUR	2	8	1274	1184	90	DUE TO SYSTEM CONDITION
		9	20				AS Per MOD
		48	76				DUE TO SYSTEM CONDITION
		82	96				
12	BHUSAWAL-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
13	INDIABULL TO MSEDC	2	10	245	172	73	DUE TO SYSTEM CONDITION
		11	20				AS Per MOD
		48	76				DUE TO SYSTEM CONDITION
		82	96				
14	KHAPERKHEDA-U 1 TO 4	2	10	482	423	59	DUE TO SYSTEM CONDITION
		11	20	411	406	5	AS Per MOD
		48	76				DUE TO SYSTEM CONDITION
		83	96				
15	PARAS-3	2	12	182	164	18	DUE TO SYSTEM CONDITION
		13	20				AS Per MOD
		48	76				DUE TO SYSTEM CONDITION
		82	96	X	X	X	DC REVISED TO BELOW TECHNICAL MINIMUM DUE TO PCQ

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
16	PARAS-4	2	13	182	168	14	DUE TO SYSTEM CONDITION
		14	20				AS Per MOD
		48	76				DUE TO SYSTEM CONDITION
		82	86	X	X	X	DC REVISED TO BELOW TECHNICAL MINIMUM DUE TO PCQ
17	KHAPERKHEDA-5	X	X	X	X	X	UNIT UNDER OUTAGE
18	JSW U 1	2	20	275	200	75	DUE TO SYSTEM CONDITION
		49	76				
		82	96				
19	AMNEPL TO REL	3	20	40	37	3	DUE TO SYSTEM CONDITION
		50	60				
20	APML U 2 TO MSEDCL	3	20	617	460	157	DUE TO SYSTEM CONDITION
		39	44	617	585	32	
		50	76	617	432	185	
		82	96	617	500	117	
21	APML U 3 TO MSEDCL	3	20	617	460	157	DUE TO SYSTEM CONDITION
		39	44	617	585	32	
		50	76	617	432	185	
		82	96	617	500	117	

TPC U 8 IN BLK(38-50 , 58-76 & 82-96) , U 5 IN BLK (38-76 & 82-96) & REL G IN BLK(56-76 & 82-96) BACKING DOWN NOT IMPLEMENTED DUE TO LINE LOADING CONSTRAINT IN MUMBAI SYSTEM.

Note :

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- MOD rates revised w.e.f 12-Sep.-2013.