

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCH SCHEDULE (in MW)		Backing Down Quantum (Max) in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT WITHDRAWN ON ECONOMIC SHUTDOWN
2	JSW RINFRA DA	1	96	263	200	63	VARIABLE SCHEDULE BLOK NO 1 TO 36 B/DAS PER SYSTEM CONDITION
3	JSW MSEDCL DA	1	96	100	70	30	AS PER SYSTEM CONDITION
4	TPC U-8	1	96	235	187	48	AS PER SYSTEM CONDITION
5	NASIK U-3, 4, 5	1	96	X	X	X	UNIT-3 SHUT DOWN D.C. TECH MIN
6	DTPS REL U1 AND U2	1	96	458	336	122	AS PER SYSTEM CONDITION
7	TPC U-5	1	96	473	292	181	AS PER SYSTEM CONDITION
8	BHUSWAL U-2 AND U-3	X	X	X	X	X	UNIT-2 AND UNIT-3 SHUT DOWN
9	RATTANINDIA U1 TO U-5	1	71	490	344	146	UNIT-3, UNIT-5, UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
		78	96	490	344	146	UNIT-3, UNIT-5, UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
10	PARLEY U-8	X	X	X	X	X	UNIT SHUT DOWN
11	KORADI U-5,6 AND U-7	X	X	X	X	X	UNIT-5, UNIT-6 SHUT DOWN, UNIT-7 SHUT DOWN
12	PARALI U-6 AND U-7	1	71	X	X	X	D.C. BELOW TECH MIN
		79	96	X	X	X	D.C. BELOW TECH MIN
13	KHAPERKHEDA U-1 TO U-4	1	71	X	X	X	D.C. TECH MIN. UNIT-1, 3,4 SHUT DOWN
		79	96	149	143	6	D.C. TECH MIN. UNIT-1, 3,4 SHUT DOWN
14	VIPL U-1 AND U-2	1	71	286	191	95	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
		79	96	286	191	95	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
15	BHUSWAL U-4 AND U-5	1	71	X	X	X	D.C. BELOW TECH MIN
		79	96	X	X	X	D.C. BELOW TECH MIN
16	KORADI U-8,9 AND 10	1	71	909	864	45	UNIT-9 SHUT DOWN AS PER SYSTEM CONDITION
		90	96	909	864	45	UNIT-9 SHUT DOWN AS PER SYSTEM CONDITION
17	ADANI 440MW PPA	1	71	249	113	136	AS PER SYSTEM CONDITION
		90	96	274	38	236	AS PER SYSTEM CONDITION
18	KHAPERKHEDA U-5	X	X	X	X	X	SHUT DOWN
19	ADANI U-1 (1200+125)MW PP	1	71	375	X	X	D.C. BELOW TECH MIN
		90	96	412	X	X	D.C. BELOW TECH MIN
20	ADANI U-4 (1200+125)MW PP	X	X	X	X	X	UNIT-4 SHUT DOWN
21	ADANI U-5 (1200+125)MW PP	1	71	375	X	X	D.C. BELOW TECH MIN
		90	96	412	X	X	D.C. BELOW TECH MIN
22	CHANDRAPUR U-3 TO U-7	1	70	684	660	24	UNIT-3 UNIT-4 UNIT -6 SHUT DOWN, AS PER SYSTEM CONDITION
		90	96	684	660	24	UNIT-3 UNIT-4 UNIT -6 SHUT DOWN, AS PER SYSTEM CONDITION
23	PARAS U-3 AND U-4	1	70	X	X	X	D.C. BELOW TECH MIN
		90	96	X	X	X	D.C. BELOW TECH MIN
24	CHANDRAPUR U-8 AND U-9	1	70	920	658	262	AS PER SYSTEM CONDITION
		90	96	920	658	262	AS PER SYSTEM CONDITION
25	JSW U-1	1	24	290	200	90	AS PER SYSTEM CONDITION
		30	69	290	200	90	AS PER SYSTEM CONDITION
26	ADANI U-2	1	23	500	432	68	AS PER SYSTEM CONDITION
		30	69	550	432	118	AS PER SYSTEM CONDITION
27	ADANI U-3	1	23	500	432	68	AS PER SYSTEM CONDITION
		30	69	550	432	118	AS PER SYSTEM CONDITION

## Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM DT. 12SEPT. 2017

3 # Indicates that back down withdrawn due to Line loading/system constraints.