

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B) X		
1	NASHIK U-3, U-4 & U-5	1	96	172	141	31	AS PER SYSTEM CONDITION/ U-3&4 UNDER
2	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
3	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
4	VIPL U-1 & U-2	X	X	X	X	X	UNITs SHUT DOWN
5	DTPS U-1 & U-2	1	28	225	168	57	AS PER SYSTEM CONDITION /U-2 OUT
		45	96	225	168	57	AS PER SYSTEM CONDITION /U-2 OUT
6	TPC U-5	1	28	460	292	168	AS PER SYSTEM CONDITION #
		45	96	460	292	168	AS PER SYSTEM CONDITION
7	TPC U-8	1	28	200	187	13	AS PER SYSTEM CONDITION #
		45	96	200	187	13	AS PER SYSTEM CONDITION
8	JSW TO AEML(DA)	1	96	300	210	90	AS PER SYSTEM CONDITION
9	DHARIWAL TO BEST	1	96	50	35	15	AS PER SYSTEM CONDITION
10	DHARIWAL TO TATA-D	1	96	50	35	15	AS PER SYSTEM CONDITION
11	KHAPERKHEDA U-1 TO U-4	1	96	144	142	2	AS PER SYSTEM CONDITION/ U-1,2&3 UNDER ZERO SCHEDULE
12	PARAS U-3 & U-4	1	96	229	164	65	AS PER SYSTEM CONDITION/ U-4 OUT
13	PARALI U-6 & U-7	1	96	229	166	63	AS PER SYSTEM CONDITION/ U-6 OUT
14	PARALI U-8	X	X	X	X	X	UNIT SHUT DOWN
15	RATTANINDIA U-1 TO U-5	1	96	980	688	292	AS PER SYSTEM CONDITION/ U-1 OUT
16	JSW TO AEML(DA)	1	96	144	100.8	43.2	AS PER SYSTEM CONDITION
17	CHANDRAPUR U-3 TO U-7	1	96	1108	954	154	AS PER SYSTEM CONDITION/ U-7 OUT
18	DHARIWAL TO MSIEDCL	1	96	160	112	48	AS PER SYSTEM CONDITION
19	CHANDRAPUR U-8 & U-9	1	96	902	656	246	AS PER SYSTEM CONDITION
20	BHUSAWAL U-4 & U-5	1	74	470	322	148	AS PER SYSTEM CONDITION/ U-4 OUT
		77	96	470	322	148	AS PER SYSTEM CONDITION/ U-4 OUT
21	KHAPERKHEDA U-5	1	74	475	335	140	AS PER SYSTEM CONDITION
		77	96	475	335	140	AS PER SYSTEM CONDITION
22	KORADI U-8 TO U-10	1	74	1295	1202	93	AS PER SYSTEM CONDITION
		77	96	1295	1202	93	AS PER SYSTEM CONDITION
23	ADANI TIRODA U-1,U-4&U-5 (PPA440 MW)	1	72	305	0	305	AS PER SYSTEM CONDITION
		77	96	305	0	305	AS PER SYSTEM CONDITION
24	ADANI TIRODA U-1,U-4&U-5 (PPA1200MW,125 MW)	1	72	917	864	53	AS PER SYSTEM CONDITION/ U-1 OUT
		77	96	917	864	53	AS PER SYSTEM CONDITION/ U-1 OUT
25	JSW U-1	1	71	285	200	85	AS PER SYSTEM CONDITION
		77	96	285	200	85	AS PER SYSTEM CONDITION
26	ADANI U-2 & U-3	1	71	1246	864	382	AS PER SYSTEM CONDITION
		79	96	1246	864	382	AS PER SYSTEM CONDITION

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backindown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 MOD RATES REVISED FROM 15:00HRS OF 16TH APRIL2019 AS PER OLD PROCEDURE Stayed Due to Hon'ble APPELLATE TRIBUNAL order in IA No. 593 of 2019 in DFR No.1762 of 2019
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.
- 4 REVISED MOD RATES EFFECTIVE FROM 00:00HRS 16TH OCT 2019 (JSW TO AEML 144 MW DA POWER ADDED)