

ROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX\_BUS) BACKED DOWN FOR THE DATE 20/11/2018

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time)		TARGET DISPATCHED SCHEDULE (Mn)	Despatched Schedule (Min)	Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Despatched Capacity (A)			
1	DHARIWAL TO BEST	1	33	X	X	X	NO SCHEDULE
		34	57	50	35	15	A3 PER SYSTEM CONDITION
		59	72	50	35	15	A3 PER SYSTEM CONDITION
		80	92	50	35	15	A3 PER SYSTEM CONDITION
		93	96	X	X	X	NO SCHEDULE
2	TPC U-8	1	73	125	X	X	D.C. BELOW TECH MIN
		79	96	125	X	X	D.C. BELOW TECH MIN
3	BWPCL U-1.2 AND4 TO MSEDCL	1	73	80	70	10	A3 PER SYSTEM CONDITION
		79	96	X	X	X	D.C. TECH MIN
4	JBW U-2.3 AND 4TO MSEDCL	1	73	275	192.5	82.5	A3 PER SYSTEM CONDITION
		79	96	275	192.5	82.5	A3 PER SYSTEM CONDITION
5	TPC U-5	1	73	473	292	181	A3 PER SYSTEM CONDITION
		79	96	473	292	181	A3 PER SYSTEM CONDITION
6	VIPL U-1, U-2	1	73	572	382	190	A3 PER SYSTEM CONDITION
		79	96	572	382	190	A3 PER SYSTEM CONDITION
7	DTPS (AEMLU-1 AND U-2)	1	27	456	336	120	A3 PER SYSTEM CONDITION
		28	32	456	336	120	A3 PER SYSTEM CONDITION
		33	73	456	336	120	A3 PER SYSTEM CONDITION
		79	96	456	336	120	A3 PER SYSTEM CONDITION
		1	25	325	284	41	A3 PER SYSTEM CONDITION
8	NASHK U-3,U-4,U-5	1	25	325	284	41	A3 PER SYSTEM CONDITION
		79	96	325	284	41	A3 PER SYSTEM CONDITION
9	BHUSWAL U-3	1	25	X	X	X	SYSTEM SHUTDOWN
		79	96	X	X	X	SYSTEM SHUTDOWN
10	RATTANNIDIA U-1 TO U-5	1	22	490	344	146	UNIT -3,4,5 SHUT DOWN. A3 PER SYSTEM CONDITION
		79	96	490	344	146	UNIT -3,4,5 SHUT DOWN. A3 PER SYSTEM CONDITION
11	PARAJI U-6 AND U-7	1	18	229	166	63	A3 PER SYSTEM CONDITION
		79	96	229	166	63	A3 PER SYSTEM CONDITION
12	PARAJI U-8	1	18	229	166	63	A3 PER SYSTEM CONDITION
		79	96	229	166	63	A3 PER SYSTEM CONDITION
13	BHUSWAL U-4 AND U-5	1	18	658	544	114	A3 PER SYSTEM CONDITION
		82	96	658	544	114	A3 PER SYSTEM CONDITION
14	KORADI U-4 AND U-7	1	19	126	X	X	D.C. BELOW TECH MIN UNIT-7 SHUT DOWN
		82	96	126	X	X	D.C. BELOW TECH MIN UNIT-7 SHUT DOWN
15	IEPL TO MSEDCL	X	X	X	X	X	NO SCHEDULE
16	DHARIWAL TO MSEDCL	1	18	X	X	X	D.C. TECH MIN
		82	96	X	X	X	D.C. TECH MIN
17	KHAPERKHEDA U-1 TO U-4	1	18	552	402	150	A3 PER SYSTEM CONDITION
		82	96	552	402	150	A3 PER SYSTEM CONDITION
18	JBW U-1	1	18	284	198	86	A3 PER SYSTEM CONDITION
		82	96	284	198	86	A3 PER SYSTEM CONDITION
19	KORADI U-3,5,10	1	18	840	X	X	D.C. BELOW TECH MIN
		82	96	840	X	X	D.C. BELOW TECH MIN
20	KHAPERKHEDA U-5	1	18	475	335	140	A3 PER SYSTEM CONDITION
		82	96	475	335	140	A3 PER SYSTEM CONDITION
21	PARAJI U-3 AND U-4	1	18	230	168	62	A3 PER SYSTEM CONDITION
		82	96	230	168	62	A3 PER SYSTEM CONDITION
22	ADANI TIRODA U-1,4,5,6,8,9,10	1	18	440	432	8	A3 PER SYSTEM CONDITION
		82	94	440	432	8	A3 PER SYSTEM CONDITION
23	CHANDRAPUR U-3 TO U-7	3	12	1483	1268	215	A3 PER SYSTEM CONDITION
		84	96	1483	1268	215	A3 PER SYSTEM CONDITION
24	ADANI TIRODA U-1 (PPA -130MW/130MW)	5	12	442	432	10	A3 PER SYSTEM CONDITION
		84	96	442	432	10	A3 PER SYSTEM CONDITION
25	ADANI TIRODA U-4 (PPA -130MW/130MW)	5	12	442	432	10	A3 PER SYSTEM CONDITION
		82	96	442	432	10	A3 PER SYSTEM CONDITION
26	ADANI TIRODA U-5 (PPA -120MW/120MW)	82	96	442	432	10	A3 PER SYSTEM CONDITION
		5	12	828	866	172	A3 PER SYSTEM CONDITION
27	CHANDRAPUR U-8 TO U-9	88	96	828	866	172	A3 PER SYSTEM CONDITION
		X	X	X	X	X	NOBACK DOWN
28	ADANI TIRODA U-2	X	X	X	X	X	NOBACK DOWN
29	ADANI TIRODA U-3	X	X	X	X	X	NOBACK DOWN

Note :  
1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Dispatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "New Schedules".  
2 M.O.D. RATES REVISE 12TH NOV-2018  
3 # Indicates that back down withdrawn due to Line loading/system constraints.