

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

21-Feb-13

| SR. NO. | GENERATING STN. / STOA | Backing Down Period (in Time Block) | | (In MW) | | Backing Down Quantum [Max] in MW [A-B] | REMARK |
|---------|------------------------|--|----|-----------------------|--------------------------------------|--|--|
| | | FROM | TO | Declared Capacity (A) | Target Despatched Schedule (Min) (B) | | |
| 1 | TPC U-6 | X | X | X | X | X | UNIT UNDER OUTAGE |
| 2 | NASIK | 1 | 30 | 511 | 465 | 46 | AS Per MOD |
| | | 95 | 96 | | | | |
| 3 | JSW U2&4 TO MSDDL | 1 | 29 | 500 | 350 | 150 | AS Per MOD |
| | | 95 | 96 | 500 | 469 | 31 | |
| 4 | BHUSAWAL-2,3 | 1 | 26 | 161 | 155 | 6 | AS Per MOD; U 3 UNDER OUTAGE |
| 5 | TPC U-5 | 1 | 26 | 473 | 260 | 213 | AS Per MOD |
| 6 | TPC U-8 | 1 | 24 | 235 | 180 | 55 | AS Per MOD |
| 7 | KORADI 5,6,7 | 2 | 23 | 315 | 308 | 7 | AS Per MOD |
| 8 | PARLI 3,4,5 | X | X | X | X | X | UNITS UNDER OUTAGE DUE TO WATER SHORTAGE |
| 9 | REL G | 2 | 23 | 479 | 336 | 143 | AS Per MOD |
| 10 | BHUSAWAL-4 | 4 | 20 | 420 | 322 | 98 | AS Per MOD |
| 11 | K'KHEDA U-1,2,3,4 | 5 | 20 | 691 | 620 | 71 | AS Per MOD |
| 12 | PARALI-6 | X | X | X | X | X | UNIT UNDER OUTAGE DUE TO WATER SHORTAGE |
| 13 | JSW U-1 | X | X | X | X | X | DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM |
| 14 | CHANDRAPUR | 8 | 18 | 1387 | 1259 | 128 | AS Per MOD |

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-Feb.-2013.