

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

21-May-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	32	483	145	338	AS PER MOD
		33	36	483	205	278	
		37	41	483	325	158	
		42	62	483	385	98	
		63	65	483	415	68	DUE TO SYSTEM CONDITION
		70	87	483	290	193	AS PER MOD
		88	96	483	230	253	
2	NASIK	7	31	516	465	51	AS PER MOD
		73	77				
3	BHUSAWAL 2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
4	VIPL TO MSEDCL	9	12	X	X	X	#
		13	30	85	59.5	25.5	AS PER MOD
		73	77				
5	JSW U-2,4-MSEDCL	13	29	250	175	75	AS PER MOD
		73	77				
6	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
7	REL G	17	22	475	400	75	AS PER MOD
		26	27	475	473	2	
8	JSW U-1	7	9	275	157	118	DUE TO LINE CONSTRAINT@
		10	31	275	230	45	

SCHEDULE WAS REDUCED AS PER MOD. BUT, BACKDOWN WAS WITHDRAWN DUE TO REAL TIME SYSTEM CONDITIONS.

@ Load Reduction in U#1 due to 400KV Jaigad-Karad (Line#3) and New Koyna-Karad ckt in tripping condition.

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-May-2013.