| SR. NO. | GENERATING STN. / STOA | Backing Down Period (in Time Block) | | Target Despatch Schedule (in MW) | | Backing Down Quantum [Max] in MW [A-B] | REMARK |
|------------|--|--|----|-------------------------------------|-------------------------------------|--|--|
| | | FROM | то | Declared Capacity (A) | Despatched Schedule (Min) (B) | | |
| 1 | NASIK U-3, U-4 & U-5 | х | х | х | х | x | U-3&4 UNDER ZERO SCHEDULE & U-5 UNDER CASE-IV |
| 2 | BHUSAWAL U-3 | Х | Х | Х | Х | Х | UNIT UNDER ZERO SCHEDULE |
| 3 | KORADI U-6 & U-7 | Х | Х | Х | Х | Х | UNITS UNDER ZERO SCHEDULE |
| 4 | VIPL U-1 & U-2 | Х | Х | Х | Х | Х | UNITS SHUT DOWN |
| 5 | TPC U-8 | Х | Х | Х | Х | Х | UNIT UNDER ZERO SCHEDULE |
| 6 | TPC U-5 | 1 | 96 | 470 | 292 | 178 | AS PER SYSTEM CONDITION |
| 7 | DTPS U-1 & U-2 | 1 | 47 | 455 | 336 | 119 | AS PER SYSTEM CONDITION |
| | | 77 | 82 | 455 | 336 | 119 | AS PER SYSTEM CONDITION |
| 8 | RATTANINDIA U-1 TO U-5 | Х | Х | Х | Х | Х | UNITS UNDER ZERO SCHEDULE |
| 9 | PARALI U-6 & U-7 | Х | Х | Х | Х | Х | UNITS UNDER ZERO SCHEDULE |
| 10 | BHUSAWAL U-4 & U-5 | Х | Х | Х | Х | Х | UNITS UNDER ZERO SCHEDULE |
| 11 | PARALI U-8 | Х | Х | Х | Х | Х | UNIT UNDER ZERO SCHEDULE |
| 12 | APML U-1,U-4 & U-5 (PPA440 MW) | х | х | х | х | х | UNDER ZERO SCHEDULE |
| 13 | KORADI U-8 TO U-10 | 78 | 82 | Х | Х | Х | DC TECH MIN |
| 14 | APML U-1,U-4 & U-5 (PPA1200MW,125 MW) | 78 | 82 | 1399 | 1296 | 103 | AS PER SYSTEM CONDITION |
| 15 | CHANDRAPUR U-3 TO U-7 | 78 | 82 | 1558 | 1274 | 284 | AS PER SYSTEM CONDITION |
| 16 | PARAS U-3 & U-4 | 78 | 82 | 208 | 166 | 42 | AS PER SYSTEM CONDITION/ U-4 OUT |
| 17 | CHANDRAPUR U-8 & U-9 | 78 | 82 | 870 | 656 | 214 | AS PER SYSTEM CONDITION |
| 18 | KHAPERKHEDA U-1 TO U-4 | Х | Х | Х | Х | Х | NO BACK DOWN |
| 19 | DHARIWAL to MSEDCL (Case-IV) | х | х | х | х | х | NO BACK DOWN |
| 20 | KHAPERKHEDA U-5 | Х | Х | Х | Х | Х | NO BACK DOWN |
| 21 | DHARIWAL to MSEDCL_DA | Х | Х | Х | Х | Х | NO BACK DOWN |
| 22 | JSW U-1 | Х | Х | Х | Х | Х | NO BACK DOWN |
| 23 | SWPGL to BEST | Х | Х | Х | Х | Х | NO BACK DOWN |
| 24 | APML U-2 & U-3 | Х | Х | Х | Х | Х | NO BACK DOWN |

Note:

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch.

 Maximum backindown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- # Indicates that back down withdrawn due to Line loading/system constraints.

 * Indicates that back down implemented due to Line loading/system constraints.

 Revised MOD Rates effective from 00:00 hrs of 12th May 2020