

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Targat Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	36	496	425	71	AS Per MOD
		37	48				DUE TO SYSTEM CONDITION
		49	64				AS Per MOD
		65	96				DUE TO SYSTEM CONDITION
3	TPC U-8	12	36	235	172	63	DUE TO SYSTEM CONDITION
		88	96				
4	TPC U-5	12	35	473	292	181	DUE TO SYSTEM CONDITION
		88	96				
5	PARALI-6	1	6	200	166	34	DUE TO SYSTEM CONDITION
		7	33	200	166	34	AS Per MOD
		41	92				DUE TO SYSTEM CONDITION
6	PARALI 3,4,5	1	6	145	138	7	DUE TO SYSTEM CONDITION
		7	22				AS Per MOD
		23	30				DUE TO SYSTEM CONDITION
		41	92				
7	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	PARALI-7	1	7	200	166	34	DUE TO SYSTEM CONDITION
		8	21				AS Per MOD
		22	30				DUE TO SYSTEM CONDITION
		41	92				
10	REL G	12	23	479	336	143	DUE TO SYSTEM CONDITION
		89	92				
11	CHANDRAPUR	1	23	1301	1189	112	DUE TO SYSTEM CONDITION
		25	96	X	X	X	DC REVISED TO BELOW TECHNICAL MINIMUM DUE TO PCQ
12	BHUSAWAL-4	41	48	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
		49	92	350	322	28	DUE TO SYSTEM CONDITION
13	INDIABULL TO MSEDCL	1	23	245	172	73	DUE TO SYSTEM CONDITION
		42	92				
14	KHAPERKHEDA-U 1 TO 4	1	22	477	423	54	DUE TO SYSTEM CONDITION
		41	82	X	X	X	DC REVISED TO BELOW TECHNICAL MINIMUM DUE TO PCQ
		83	92				DUE TO SYSTEM CONDITION
15	PARAS-3	1	22	191	164	27	DUE TO SYSTEM CONDITION
		23	96	X	X	X	DC REVISED TO BELOW TECHNICAL MINIMUM DUE TO PCQ

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
16	PARAS-4	1	22	191	168	23	DUE TO SYSTEM CONDITION
		23	96	X	X	X	DC REVISED TO BELOW TECHNICAL MINIMUM DUE TO PCQ
17	KHAPERKHEDA-5	X	X	X	X	X	UNIT UNDER OUTAGE
18	JSW U 1	1	22	275	200	75	DUE TO SYSTEM CONDITION
		41	92				
19	AMNEPL TO REL	1	22	40	37	3	DUE TO SYSTEM CONDITION
		23	96	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
20	APML U 2 TO MSEDCL	1	20	617	432	185	DUE TO SYSTEM CONDITION
		41	60				
		61	74	617	500	117	
		82	92	617	550	67	
21	APML U 3 TO MSEDCL	1	20	617	432	185	DUE TO SYSTEM CONDITION
		41	60				
		61	74	617	500	117	
		82	92	617	550	67	

TPC U 8 IN BLK(41-87) , U 5 IN BLK (41-87) & REL G IN BLK(41-88) BACKING DOWN NOT IMPLEMENTED DUE TO LINE LOADING CONSTRAINT IN MUMBAI SYSTEM.

**Note :**

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- MOD rates revised w.e.f 12-Sep.-2013.