

## STATEMENT OF GENERATOR / STOA SCHEDULES (EX\_BUS) BACKED DOWN FOR THE DATE:

**21-Nov-12**

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	40	483	145	338	AS Per MOD
		76	96				
		41	75	483	200	283	
2	TPC U-5	1	39	473	260	213	AS Per MOD
		89	96				
		77	88	473	315	158	
3	JSW U4 TO MSEDCL	x	x	x	x	x	MSEDCL REQUIREMENT OF TECHNICAL MINIMUM
4	JSW U2 TO MSEDCL	x	x	x	x	x	MSEDCL REQUIREMENT OF TECHNICAL MINIMUM
5	NASIK	x	x	x	x	x	DC REVISED DUE TO UNIT-3 TRIPPED
		90	96	486	472	14	AS Per MOD
6	TPC U-8	1	27	235	180	55	AS Per MOD
		90	96	235	180	55	
7	BHUSAWAL-2,3	1	26	161	155	6	AS Per MOD
		92	96				
8	KORADI	x	x	x	x	x	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	PARALI U# 3,4,5	x	x	x	x	x	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
10	REL-G	1	26	479	336	143	AS Per MOD
		92	96	480	336	144	
11	K'KHEDA U-1,2,3,4	1	17	802	786	16	AS Per MOD
		18	25	X	X	X	#
12	JSW U#1	1	9	275	190	85	AS Per MOD
		10	25	X	X	X	#
		94	96	275	204	71	AS Per MOD
13	PARALI U#6	X	X	X	X	X	UNIT NOT ON BAR
14	CHANDRAPUR	1	8	1810	1546	264	AS Per MOD

# SCHEDULE WAS REDUCED AS PER MOD. BACKDOWN WAS WITHDRAWN DUE TO REAL TIME SYSTEM CONDITIONS.

**Note :**

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 11-Nov-2012.