

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

22-Jan-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT WAS UNDER OUTAGE, SET SYN ON 06:45HRS FOR MAINTAINING THE SCH. OF TPC U 5
2	NASIK	1	33	521	465	56	AS Per MOD
		68	74				
		83	96				
3	APML(TIRODA) - MSEDCL	1	31	X	X	X	DC REVISED BY LM CELL
		68	74	X	X	X	
		84	96	X	X	X	
4	JSW U2&4 TO MSEDCL	1	31	300	210	90	AS Per MOD
		68	74	300	210	90	DC REVISED BY LM CELL
		84	96	300	210	90	
5	TPC U-5	1	31	473	260	213	AS Per MOD
		84	96	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM #
6	TPC U-8	1	23	230	180	50	AS Per MOD
		87	87	230	225	5	
		88	92	230	180	50	DUE TO SYSTEM CONDITION
		93	96	230	180	50	AS Per MOD
7	BHUSAWAL-2,3	1	22	322	310	12	AS Per MOD
		88	88	322	310	12	
		89	92	322	310	12	DUE TO SYSTEM CONDITION
		93	96	322	310	12	AS Per MOD
8	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	REL G	1	21	479	336	143	AS Per MOD
		88	88	480	389	91	
		89	96	480	336	144	DUE TO SYSTEM CONDITION
10	PARLI 3,4,5	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
11	BHUSAWAL-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
		89	96	400	322	78	DUE TO SYSTEM CONDITION
12	K'KHEDA U-1,2,3,4	3	20	667	620	47	AS Per MOD
		89	96	667	593	74	DUE TO SYSTEM CONDITION
13	JSW U-1	4	20	275	190	85	AS Per MOD
		89	96	275	190	85	DUE TO SYSTEM CONDITION

14	PARALI-6	5	20	225	164	61	AS Per MOD
15	CHANDRAPUR	6	20	1668	1382	286	AS Per MOD
16	PARALI-7	X	X	X	X	X	UNIT UNDER OUTAGE
17	K'KHEDA-5	9	19	471	335	136	AS Per MOD
18	PARAS-3,4	9	18	460	328	132	AS Per MOD
19	JSW 2&4 TO REL	10	18	96	67	29	AS Per MOD
20	WPCL TO REL	10	18	256	179	77	AS Per MOD

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-Jan.-2013.

3 # TPC U 5 Gen Restricted to 230 MW(Ex-Bus) & over an above sch. Maintained by TPC U 6