

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							22-Jan-17
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT SHUTDOWN
2	REL DAHANU U 1&2	1	28	467	336	131	AS PER SYSTEM CONDITION
		70	96	467	336	131	AS PER SYSTEM CONDITION
3	NASIK	1	28	354	283	71	UNIT-3 W/DN FOR ZERO SCHEDULE BY MSEDCL, B/D AS PER SYSTEM CONDITION
		70	96	354	283	71	UNIT-3 W/DN FOR ZERO SCHEDULE BY MSEDCL, B/D AS PER SYSTEM CONDITION
4	TPC U8	1	27	235	187	48	AS PER SYSTEM CONDITION
		70	96	235	187	48	AS PER SYSTEM CONDITION
5	TPCU5	X	X	X	X	X	UNIT SHUT DOWN
6	RATTANINDIA U1,2,3,4,5	X	X	X	X	X	UNIT-1,2,3,4,5 W/DNFOR ZERO SCHEDULE BY MSEDCL
7	BHUSWAL 2,3	X	X	X	X	X	UNIT-2 AND UNIT-3 W/DN FOR ZERO SCHEDULE
8	KORADI U-5 TO U-7	1	9	X	X	X	UNIT-6 SHUT DOWN UNI-5 SHUT DOWN UNIT-7 D.C. TECH MIN.
		10	27	X	X	X	UNIT-6 SHUT DOWN UNI-5 SHUT DOWN UNIT-7 TRIPPED AT 1:47HRS
		72	96	X	X	X	UNIT-6 SHUT DOWN UNI-5 SHUT DOWN UNIT-7 TRIPPED AT 1:47HRS
9	KHAPERKHEDA U1 TO U4	1	27	722	572	150	AS PER SYSTEM CONDITION
		72	96	722	572	150	AS PER SYSTEM CONDITION
10	PARLYU-8	X	X	X	X	X	UNIT SHUT DOWN
11	KHAPERKHEDA U-5	1	24	480	335	145	AS PER SYSTEM CONDITION
		73	96	480	335	145	AS PER SYSTEM CONDITION
12	BHUSWAL U-4AND U-5	1	24	940	644	296	AS PER SYSTEM CONDITION
		78	96	940	644	296	AS PER SYSTEM CONDITION
13	PARAS U-3 AND U-4	1	24	230	168	62	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
		78	96	230	168	62	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
14	PARLEY U-6 AND U-7	1	24	229	168	61	UNIT-6 SHUT DOWN, B/D AS PER SYSTEM CONDITION
		78	96	229	168	61	UNIT-6 SHUT DOWN, B/D AS PER SYSTEM CONDITION
15	VIPL U1,2	1	21	273	191	82	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
		78	96	273	191	82	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
16	ADANI U1	X	X	X	X	X	UNIT-1SHUT DOWN
17	ADANI U4	1	21	X	X	X	D.C. TECH MIN
		79	96	X	X	X	D.C. TECH MIN
18	ADANI U5	1	21	X	X	X	D.C. TECH MIN
		79	96	X	X	X	D.C. TECH MIN
19	KORADI U8 ,U9,10	1	20	625	432	193	UNIT-8 SHUT DOWN, UNIT-10 SHUT DOWN,B/D AS PER SYSTEM CONDITION
		80	96	966	811	155	UNIT-8 SHUT DOWN, UNIT-10 SYN. 5:09HRS ,B/D AS PER SYSTEM CONDITION
20	CHANDRAPURU3 TO U7	1	20	1210	954	256	UNIT-6 SHUT DOWN B/DAS PER SYSTEM CONDITION
		80	96	1187	954	233	UNIT-6 SHUT DOWN B/DAS PER SYSTEM CONDITION
21	CHANDRAPUR U8AND U9	1	20	948	658	290	B/DAS PER SYSTEM CONDITION
		80	96	948	658	290	B/DAS PER SYSTEM CONDITION
22	ADANI UNIT-2	1	20	X	X	X	D.C. TECH MIN
		88	96	X	X	X	D.C. TECH MIN
23	ADANI U-3	1	20	X	X	X	D.C. TECH MIN
		88	96	X	X	X	D.C. TECH MIN
24	JSW U-1	X	X	X	X	X	UNIT SHUT DOWN

X

NOTE:

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- M.O.D RATES R1 EFFECTIVE FROM 21 JAN2017
- # Indicates that back down withdrawn due to Line loading/system constraints.