

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

22-Apr-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	36	483	145	338	AS Per MOD
		37	72	483	290	193	
		73	91	483	230	253	
		92	96	483	170	313	
2	NASIK	1	1	354	310	44	DUE TO SYSTEM CONDITION
		2	32				AS Per MOD
3	JSW U2&4 TO MSEDCL	1	27	X	X	X	DC REVISED BY LM CELL
		28	34	490	350	140	DUE TO SYSTEM CONDITION
4	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
5	TPC U-5	1	32	473	260	213	DUE TO SYSTEM CONDITION
6	TPC U-8	14	28	235	180	55	DUE TO SYSTEM CONDITION
7	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	PARLI 3,4,5	X	X	X	X	X	UNITS UNDER OUTAGE DUE TO WATER SHORTAGE
9	REL G	4	28	478	336	142	DUE TO SYSTEM CONDITION

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 18-April-2013.