

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							22-Apr-17
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT SHUTDOWN
2	TPC U-8	7	27	235	187	48	AS PER SYSTEM CONDITION
		53	76	235	187	48	AS PER SYSTEM CONDITION
3	TPC U-5	7	27	473	292	181	AS PER SYSTEM CONDITION
		53	76	473	292	181	AS PER SYSTEM CONDITION
4	NASIK	10	26	364	283	81	UNIT-3 CONVERTED TO ZERO SCHEDULE BY MSEDCL ON DT. FROM 10/04/2017 1:05HRS. B/D AS PER SYSTEM CONDITION
		54	76	364	283	81	UNIT-3 CONVERTED TO ZERO SCHEDULE BY MSEDCL ON DT. FROM 10/04/2017 1:05HRS. B/D AS PER SYSTEM CONDITION
5	REL DAHANU U1 AND U2	54	60	462	336	126	AS PER SYSTEM CONDITION
		65	75	462	336	126	AS PER SYSTEM CONDITION
6	JSW PTC TO REL DA	55	60	X	X	X	NO SCHEDULE
		66	76	X	X	X	LESS SCHEDULE ,VARIABLE SCHEDULE BLK NO.75 TO 96
7	RATTANINDIA U1,2,3,4,5	66	76	X	X	X	D.C. TECH MIN UNIT-4 AND UNIT-5 , UNIT-3 SHUT DOWN
8	BHUSWAL U2,3	66	76	152	144	8	AS PER SYSTEM CONDITION UNIT-2 SHUT DOWN
9	KORADI U-5 TO U-7	66	68	X	X	X	UNIT-7 RUNNING BELOW TECH MIN.UNIT-5 AND UNIT-6 SHUT DOWN
		69	75	X	X	X	UNIT-7 TRIPPED AT 17:53HRS UNIT-5 AND UNIT-6 SHUT DOWN
10	KHAPERKHEDA U1 TO U4	66	75	639	572	67	AS PER SYSTEM CONDITION
11	PARLY U-6 AND U7	66	75	458	332	126	AS PER SYSTEM CONDITION
12	BHUSWAL U-4AND U-5	66	75	940	644	296	AS PER SYSTEM CONDITION
13	KHAPERKHEDA U-5	66	75	418	335	83	AS PER SYSTEM CONDITION
14	PARLY U-8	67	75	200	168	32	AS PER SYSTEM CONDITION
15	PARAS U3 AND U-4	67	73	230	168	62	AS PER SYSTEM CONDITION UNIT-3 SHUT DOWN
16	VIPL U1 AND U2	67	73	273	191	82	AS PER SYSTEM CONDITION
17	KORADI U8 ,U9,10	67	70	1117	864	253	AS PER SYSTEM CONDITION
		71	73	492	432	60	UNIT-10 TRIPPED 17:29HRS AND SYN. 21:17HRS B/DAS PER SYSTEM CONDITION
18	ADANI 440 PPA	X	X	X	X	X	NO BACK DOWN
19	ADANI U-1(1200MW &125MW PPA)	X	X	X	X	X	UNIT SHUTDOWN
20	ADANI U-4(1200MW &125MW PPA)	X	X	X	X	X	NO BACK DOWN
21	ADANI U-5(1200MW &125MW PPA)	X	X	X	X	X	NO BACK DOWN
22	CHANDRAPUR U3 TO U7	X	X	X	X	X	NO BACK DOWN UNIT-7 SHUT DOWN.
23	CHANDRAPUR U8 AND U9	X	X	X	X	X	NO BACK DOWN UNIT-9 SHUT DOWN
24	ADANI UNIT-2	X	X	X	X	X	NO BACK DOWN
25	ADANI U-3	X	X	X	X	X	NO BACK DOWN
26	JSW U-1	X	X	X	X	X	NO BACK DOWN

NOTE:

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D RATES EFFECTIVE FROM 12TH APRIL 2017
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.