

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

22-May-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	39	483	145	338	AS PER MOD
		40	46	483	270	213	
		47	53	483	300	183	DUE TO SYSTEM CONDITION
		54	66	483	330	153	AS PER MOD
		67	77	483	330	153	DUE TO SYSTEM CONDITION
		78	96	483	240	243	
2	NASIK	6	32	X	X	X	#
		36	36	511	466	45	AS PER MOD
		73	77	511	465	46	
3	BHUSAWAL 2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
4	JSW U-2,4-MSEDCL	9	32	X	X	X	#
		73	77	250	175	75	AS PER MOD
5	VIPL TO MSEDCL	11	31	X	X	X	#
		73	77	85	59.5	25.5	AS PER MOD
6	REL G	11	30	X	X	X	BACKING DOWN W/DN DUE TO LINE LOADING CONSTRAINT IN MUMBAI SYSTEM #
		73	77				
7	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	TPC U-5	9	28	X	X	X	BACKING DOWN W/DN DUE TO LINE LOADING CONSTRAINT IN MUMBAI SYSTEM #
		74	77	X	X	X	
9	TPC U-8	13	21	X	X	X	
		74	76	X	X	X	
10	BHUSAWAL-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
11	K'KHEDA U-1,2,3,4	16	19	X	X	X	DC REVISED TO BELOW THE TECHNICAL MINIMUM DUE TO CHP PROBLEM

SCHEDULE WAS REDUCED AS PER MOD. BUT, BACKDOWN WAS WITHDRAWN DUE TO REAL TIME SYSTEM CONDITIONS.

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-May-2013.