

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							22-Jun-17
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT SHUT DOWN
2	NASHIK	1	9	X	X	X	# B/D AS PER SYSTEM CONDITION, UNIT-5 CONVERTED TO ZEROSCHEDULE BY MSEDCL
		10	40	364	284	80	B/D AS PER SYSTEM CONDITION, UNIT-5 CONVERTED TO ZEROSCHEDULE BY MSEDCL
		41	48	X	X	X	# B/D AS PER SYSTEM CONDITION, UNIT-5 CONVERTED TO ZEROSCHEDULE BY MSEDCL
		49	96	364	284	80	B/D AS PER SYSTEM CONDITION, UNIT-5 CONVERTED TO ZEROSCHEDULE BY MSEDCL
3	REL DAHANU U1 AND U2	1	9	X	X	X	#
		10	24	464	336	128	AS PER SYSTEM CONDITION
		25	96	X	X	X	#
4	TPC U-8	1	96	X	X	X	#
5	TPC U-5	X	X	X	X	X	UNIT SHUT DOWN
6	RATTANINDIA U1,2,3,4,5	X	X	X	X	X	unit-2 , UNIT-5 W/DN , UNIT-4 W/DN RS FOR ZERO SCHEDULE BY MSEDCL, UNIT-1 AND UNIT-3 SHUT DOWN
7	BHUSWAL U2,3	X	X	X	X	X	UNIT-2 SHUT DOWN, UNIT-3 W/DN FOR ZERO SCHEDULE BY MSEDCL
8	PARLEY U-6 AND U-7	X	X	X	X	X	UNIT-7 and UNIT-6 FOR ZERO SCHEDULE BY MSEDCL AS PER SYSTEM CONDITION
9	PARLEY U-8	X	X	X	X	X	UNIT-8 W/DN FOR ZERO SCHEDULE BY MSEDCL
10	BHUSWAL U-4 AND U-5	1	96	940	644		AS PER SYSTEM CONDITION
12	KHAPERKHEDA U1 TO U4	1	96	X	X	X	UNIT-2 SHUT DOWN D.C. BELOW TECH MIN
13	KORADI-5,6,7	X	X	X	X	X	UNIT-5 , UNIT-6 SHUT DOWN UNIT -7 SHUT DOWN
14	VIPL U1,2	1	96	286	191	95	UNIT-1 SHUT DOWN, B/D AS PER SYSTEM CONDITION
15	KHAPERKHEDA U-5	1	96	475	335	140	AS PER SYSTEM CONDITION
16	KORADI U8 ,U9,10	1	28	1488	1296	192	AS PER SYSTEM CONDITION
		29	60	1611	1296	315	AS PER SYSTEM CONDITION
		61	96	1469	1296	173	AS PER SYSTEM CONDITION
17	PARAS U-3 AND U-4	1	96	230	164	66	AS PER SYSTEM CONDITION UNIT-4 SHUT DOWN
18	ADANI 440 PPA	1	96	440	33.99	406.41	AS PER SYSTEM CONDITION
19	CHANDRAPUR U3 TO U7	1	23	1461	1134	327	AS PER SYSTEM CONDITION
		34	96	1461	1134	327	AS PER SYSTEM CONDITION
20	ADANI U-1(1200MW &125MW PPA)	1	23	421	X	X	D.C BELOW TECH MIN
		34	96	421	X	X	D.C BELOW TECH MIN
21	ADANI U-4(1200MW &125MW PPA)	1	23	421	X	X	D.C BELOW TECH MIN
		34	96	421	X	X	D.C BELOW TECH MIN
22	ADANI U-5(1200MW &125MW PPA)	1	23	421	X	X	D.C BELOW TECH MIN
		34	96	421	X	X	D.C BELOW TECH MIN
23	CHANDRAPUR U8 AND U9	1	23	948	658	290	AS PER SYSTEM CONDITION
		34	96	834	658	176	AS PER SYSTEM CONDITION
24	ADANI UNIT-2	1	18	623	432	191	AS PER SYSTEM CONDITION
		35	96	623	432	191	AS PER SYSTEM CONDITION
25	ADANI U-3	1	18	623	432	191	AS PER SYSTEM CONDITION
		35	96	623	432	191	AS PER SYSTEM CONDITION
26	JSW U-1	1	18	255	200	55	AS PER SYSTEM CONDITION
		35	44	255	200	55	AS PER SYSTEM CONDITION
		66	91	255	200	55	AS PER SYSTEM CONDITION

NOTE:

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D RATES EFFECTIVE FROM 12TH JUNE 2017
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.