

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

22-Aug-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	96	364	283	81	DUE TO SYSTEM CONDITION
3	TPC U-8	1	31	235	172	63	AS Per MOD
		69	73				
		87	96				
4	TPC U-5	1	28	473	292	181	AS Per MOD
		71	72	473	440	33	
		93	96	473	380	93	
5	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
6	PARALI 5,6,7	X	X	X	X	X	NO SCHEDULE
7	BHUSAVAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	REL G	3	22	479	336	143	AS Per MOD
9	BHUSAVAL-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
10	PARALI-7	5	21	230	166	64	AS Per MOD
		22	30				DUE TO SYSTEM CONDITION
		31	32	210	166	44	
		48	56	190	166	24	
11	PARALI-6	7	21	230	166	64	AS Per MOD
		22	32				DUE TO SYSTEM CONDITION
		48	56	210	166	44	
12	INDIABULL TO MSEDCL	8	20	245	172	73	AS Per MOD
		48	56				DUE TO SYSTEM CONDITION
13	KHAPERKHEDA-5	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
14	KHAPERKHEDA-U 1 TO 4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
15	CHANDRAPUR	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
16	PARAS-3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
17	PARAS-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
18	JSW U 1	7	96	X	X	X	UNIT W/DN
19	AMNEPL TO REL	X	X	X	X	X	UNIT SHUT DOWN
20	APML U 2 TO MSEDCL	13	27	617	500	117	DUE TO LINE CONSTRAINT
		49	64	617	460	157	
21	APML U 3 TO MSEDCL	13	27	617	500	117	DUE TO LINE CONSTRAINT
		49	64	617	460	157	

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 13-Aug.-2013.