

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							22-Aug-16
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT SHUTDOWN
2	NASIK	5	19	354	284	70	AS PER SYSTEM CONDITION ;UNIT-5 ZERO SCHEDULE BY MSEDCL
3	BHUSWAL U 2,3	X	X	X	X	X	MSEDCL W/DN UNIT-3 FOR ZERO SCHEDULE AND UNIT-2SHUT DOWN
4	REL DAHANU U 1&2	6	19	470	336	134	AS PER SYSTEM CONDITION
5	TPC U-5	6	16	473	292	181	AS PER SYSTEM CONDITION
6	TPC U-8	6	16	235	187	48	AS PER SYSTEM CONDITION
7	RATAN INDIA U-1,2,3,4,5.	X	X	X	X	X	MSEDCL W/DN UNIT- 1 TO 5 FOR ZERO SCHEDULE
8	BHUSWAL U -4 AND U-5	X	X	X	X	X	UNIT-4 W/DN AND UNIT-5 W/DN BY MSEDCLFOR ZERO SCHEDULE
9	VIPL U1&2	X	X	X	X	X	NO BACK DOWN
10	KORADI U-5 TO U-7	X	X	X	X	X	UNIT-6 SHUT DOWN UNIT-5 AND UNIT-7 W/DN BY MSEDCL FOR ZERO SCHEDULE
11	KHAPERKHEDA U1 TO U4	X	X	X	X	X	AS PER SYSTEM CONDITION UNIT-3 W/DN FOR AOH . MSEDCL W/DN UNIT-2 UNIT-4 UNIT-1 FOR ZERO SCHEDULE
12	ADANI U-1	X	X	X	X	X	NO BACK DOWN
13	ADANI U-4	X	X	X	X	X	NO BACK DOWN
14	ADANI U-5	X	X	X	X	X	NO BACK DOWN
15	PARAS U-3 AND U-4	X	X	X	X	X	NO BACK DOWN
16	CHANDRAPUR U-3 to 7	X	X	X	X	X	NO BACK DOWN
17	KORADI U-8	X	X	X	X	X	NO BACK DOWN
18	CHANDRAPUR U-8	X	X	X	X	X	NO BACK DOWN
19	KHAPERKHEDA U-5	X	X	X	X	X	NO BACK DOWN
20	ADANI U-3	X	X	X	X	X	NO BACK DOWN
21	ADANI U-2	X	X	X	X	X	NO BACK DOWN
22	JSW U-1	X	X	X	X	X	NO BACK DOWN
NOTE-							

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D. RATES REVISED FROM 12 TH OF AUG 2016
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.