

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Targat Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	78	506	425	81	AS Per MOD
		89	96				
3	TPC U-8	1	76	235	172	63	AS Per MOD
		89	96				
4	TPC U-5	1	8	473	292	181	AS Per MOD
		9	76	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
		93	96	473	310	163	DUE TO SYSTEM CONDITION
5	PARALI-6	1	41	180	166	14	AS Per MOD
		45	74	180	166	14	
		75	76				
		93	96				
6	PARALI 3,4,5	1	40	145	138	7	AS Per MOD
		45	74				
		75	76				DUE TO SYSTEM CONDITION
		93	96				
7	KORADI 5,6,7	1	44	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
		45	49	306	299	7	DUE TO SYSTEM CONDITION
		50	76	162	155	7	DUE TO SYSTEM CONDITION, UNIT 5 TRIPPED
		93	96				
8	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	PARALI-7	1	40	180	166	14	AS Per MOD
		45	73				
		74	76				DUE TO SYSTEM CONDITION
		93	96				
10	REL G	1	31	479	336	143	AS Per MOD
		54	72				DUE TO SYSTEM CONDITION
		73	75				
		94	96				
11	CHANDRAPUR	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
12	BHUSAWAL-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
13	INDIABULL TO MSEDCL	5	20	245	172	73	AS Per MOD
		26	96	245	0	245	DUE TO LINE CONSTARINT#
14	KHAPERKHEDA-U 1 TO 4	6	20	618	570	48	AS Per MOD
		58	74	451	428	23	DUE TO SYSTEM CONDITION
		94	96				

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
15	PARAS-3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
16	PARAS-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
17	KHAPERKHEDA-5	X	X	X	X	X	UNIT UNDER OUTAGE
18	JSW U 1	7	12	275	200	75	DUE TO SYSTEM CONDITION
		13	19				AS Per MOD
		58	74				DUE TO SYSTEM CONDITION
		95	96				
19	AMNEPL TO REL	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
20	APML U 2 TO MSEDCL	8	32	617	432	185	DUE TO SYSTEM CONDITION
		61	71				
		96	96	617	580	37	
21	APML U 3 TO MSEDCL	8	32	617	432	185	DUE TO SYSTEM CONDITION
		61	71				
		96	96	617	580	37	
REL G IN BLK(32-53) BACKING DOWN NOT IMPLEMENTED DUE TO LINE LOADING CONSTRAINT IN MUMBAI SYSTEM.							
# INDIABULL GEN SCH.RESTRICTED TO BE ZERO DUE TO TRIPPING OF 400KV KORADI-INDIABULL & KORADI-AKOLA LINE							
APML U 2,3 SCH.REVISED IN BLK(19-22) UPTO TECHNICAL MINIMUM DUE TO STABILITY PROBLEM							

**Note :**

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- MOD rates revised w.e.f 12-Sep.-2013.