

| STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE: | | | | | | <u>22-Sep-14</u> | R0 |
|--|------------------------|-------------------------------------|----|------------------------------------|-------------------------------|--|----------------------------------|
| SR. NO. | GENERATING STN. / STOA | Backing Down Period (in Time Block) | | TARGET DESPATCHED SCHEDULE (in MW) | | Backing Down Quantum [Max] in MW [A-B] | REMARK |
| | | FROM | TO | Declared Capacity (A) | Despatched Schedule (Min) (B) | | |
| 1 | TPC U-6 | 1 | 96 | x | x | x | SCHEDULE AS PER SYSTEM CONDITION |
| 1 | NASIK | x | x | x | x | X | DC TECH MIN |
| 2 | PARALI-3,4,5 | 5 | 20 | 141 | 138 | 3 | DUE TO SYSTEM CONDITION |
| 5 | JSW TO TPC (DA) | 5 | 20 | 75 | 53 | 23 | DUE TO SYSTEM CONDITION |
| 6 | VIPL U-1 TO RINFRA | 5 | 20 | 230 | 190 | 40 | DUE TO SYSTEM CONDITION |
| 7 | VIPL U-2 TO RINFRA | x | x | x | x | x | UNIT SHUTDOWN |
| 3 | JSW TO REL(DA) | 5 | 20 | x | x | x | DECL BELOW TECH MIN |
| 3 | JSW TO MSEDCL | 5 | 20 | 250 | 175 | x | DUE TO SYSTEM CONDITION |
| 10 | PARLY U-6 | 5 | 20 | x | x | x | DECL TECH MIN |
| 11 | TPC U-8 | x | x | x | x | x | UNIT SHUTDOWN |
| 12 | TPC U-5 | 5 | 20 | 473 | 440 | x | AS PER MOD |

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 MOD rates revised w.e.f 12-Sept-2014.