

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE: 22.09.2017

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (B)		
1	TPC U-6	X	X	X	X	X	UNIT WITHDRAWN ON ECONOMIC SHUTDOWN
2	JSW MSDCL DA	1	72	100	70	30	AS PER SYSTEM CONDITION
		93	96	100	70	30	AS PER SYSTEM CONDITION
3	JSW RINFRA DA	1	72	377	263	114	VARIABLE SCHEDULE BLOK NO 1 TO 36 BIDAS PER SYSTEM CONDITION
		93	96	289	192	97	VARIABLE SCHEDULE BLOK NO 1 TO 36 BIDAS PER SYSTEM CONDITION
4	JSW RINFRA DA2	1	25	X	X	X	NO SCHEDULE
		27	72	X	X	X	VARIABLE SCHEDULE BLOK NO 36 TO 96 BIDAS PER SYSTEM CONDITION
		93	96	X	X	X	VARIABLE SCHEDULE BLOK NO 26 TO 96 BIDAS PER SYSTEM CONDITION
4	TPC U-8	1	72	235	187	48	AS PER SYSTEM CONDITION
		93	96	235	187	48	AS PER SYSTEM CONDITION
5	NASK U-3, 4, 5	1	72	X	X	X	UNIT-3 SHUT DOWN D.C. TECH MIN
		93	96	X	X	X	UNIT-3 SHUT DOWN D.C. TECH MIN
6	DTPS REL U1 AND U2	1	72	229	166	63	UNIT-2 SHUT DOWNAS PER SYSTEM CONDITION
		93	96	229	166	63	UNIT-2 SHUT DOWNAS PER SYSTEM CONDITION
7	TPC U-5	1	72	473	292	181	AS PER SYSTEM CONDITION
		93	96	473	330	143	AS PER SYSTEM CONDITION
8	BHUSWAL U-2 AND U-3	X	X	X	X	X	UNIT-2 AND UNIT-3 SHUT DOWN
9	RAITANINDIA U1 TO U-5	1	71	490	344	146	UNIT-3, UNIT-5,UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
		95	96	490	344	146	UNIT-3, UNIT-5,UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
10	PARLEY U-6	X	X	X	X	X	UNIT SHUT DOWN
11	KORADI U-5,AND U-7	X	X	X	X	X	UNIT-5, UNIT-6 SHUT DOWN, UNIT-7 SHUT DOWN
12	PARAJI U-6 AND U-7	1	26	X	X	X	D.C. BELOW TECH MIN
		30	71	X	X	X	D.C. BELOW TECH MIN
		96	96	X	X	X	D.C. BELOW TECH MIN
13	KHAPERKHEDA U-1 TO U-4	1	26	X	X	X	D.C. TECH MIN. UNIT-1, 3,4 SHUT DOWN
		30	71	X	X	X	D.C. TECH MIN. UNIT-1, 3,4 SHUT DOWN
		96	96	X	X	X	D.C. TECH MIN. UNIT-1, 3,4 SHUT DOWN
14	VIPL U-1 AND U-2	1	26	286	191	95	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
		30	71	286	191	95	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
15	BHUSWAL U-4 AND U-5	1	24	X	X	X	D.C. BELOW TECH MIN
		30	71	X	X	X	D.C. BELOW TECH MIN
16	KORADI U-8,9 AND 10	1	24	841	799	42	UNIT-9 SHUT DOWN AS PER SYSTEM CONDITION
		30	71	802	799	3	UNIT-9 SHUT DOWN AS PER SYSTEM CONDITION
17	ADANI 440MW PPA	1	24	299	0	299	AS PER SYSTEM CONDITION
		30	69	304	0	304	AS PER SYSTEM CONDITION
18	KHAPERKHEDAU-5	X	X	X	X	X	SHUT DOWN
19	ADANI U- 1 (1200+125)MW PP	1	24	450	432	18	AS PER SYSTEM CONDITION
		30	69	458	432	26	AS PER SYSTEM CONDITION
20	ADANI U-4 (1200+125)MW PP	X	X	X	X	X	UNIT-4 SHUT DOWN
21	ADANI U-5 (1200+125)MW PP	1	24	450	432	18	AS PER SYSTEM CONDITION
		30	69	458	432	26	AS PER SYSTEM CONDITION
22	CHANDRAPUR U-3 TO U-7	1	24	740	660	80	UNIT-3 UNIT-4 UNIT- 6 SHUT DOWN, AS PER SYSTEM CONDITION
		30	66	740	660	80	UNIT-3 UNIT-4 UNIT- 6 SHUT DOWN, AS PER SYSTEM CONDITION
23	PARAS U-3 AND U-4	1	24	X	X	X	D.C. BELOW TECH MIN
		30	66	X	X	X	D.C. BELOW TECH MIN
24	CHANDRAPUR U-8 AND U-9	1	24	862	658	204	AS PER SYSTEM CONDITION
		31	66	862	658	204	AS PER SYSTEM CONDITION
25	JSW U-1	1	24	290	200	90	AS PER SYSTEM CONDITION
		31	57	290	200	90	AS PER SYSTEM CONDITION
26	ADANI U-2	1	24	600	432	168	AS PER SYSTEM CONDITION
		33	42	623	432	191	AS PER SYSTEM CONDITION
27	ADANI U-3	1	24	600	432	168	AS PER SYSTEM CONDITION
		33	42	623	432	191	AS PER SYSTEM CONDITION

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backindown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Scheduler".

2 M.O.D. RATES REVISED FROM DT. 12SEPT. 2017

3 # Indicates that back down withdrawn due to Line loading/system constraints.