

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

22-Nov-12

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	39	483	145	338	AS Per MOD
		84	96				
		40	48	483	230	253	
		49	66	483	330	153	
		67	77	483	390	93	
		78	83	483	220	263	
2	TPC U-5	1	38	473	260	213	AS Per MOD
		87	96				
3	JSW U4 TO MSEDCL	x	x	x	x	x	MSEDCL REQUIREMENT OF TECHNICAL MINIMUM
4	JSW U2 TO MSEDCL	x	x	x	x	x	MSEDCL REQUIREMENT OF TECHNICAL MINIMUM
5	NASIK	1	24	486	465	21	AS Per MOD
		25	29	516	465	51	
6	TPC U-8	1	27	235	180	55	AS Per MOD
7	BHUSAWAL-2,3	1	24	157	155	2	AS Per MOD
8	KORADI	x	x	x	x	x	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	PARALI U# 3,4,5	x	x	x	x	x	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
10	REL-G	1	24	479	336	143	AS Per MOD
11	K'KHEDA U-1,2,3,4	4	21	480	464	16	AS Per MOD
12	JSW U#1	5	21	275	190	85	AS Per MOD
13	PARALI U#6	x	x	x	x	x	UNIT NOT ON BAR
14	CHANDRAPUR	5	21	1829	1552	277	AS Per MOD

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 11-Nov-2012.