

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	36	516	425	91	AS PER MOD
		40	58	516	477	39	
		59	96	X	X	X	
3	PARALI 3,4,5	1	4	151	138	13	AS PER MOD
		5	28	X	X	X	#
4	JSW U 2,4 TO BEST(100 MW)	X	X	X	X	X	X
5	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
6	TPC U-5	2	29	X	X	X	#
7	TPC U-8	7	20	X	X	X	
8	APML U 2 TO MSEDCL	1	96	617	432	185	Due to Line Loading system condition
9	APML U 3 TO MSEDCL						

SCHEDULE WAS REDUCED AS PER MOD. BACKDOWN WAS WITHDRAWN DUE TO REAL TIME SYSTEM CONDITIONS.

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 MOD rates revised w.e.f 12-Nov.-2013.