

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE: 22.11.2017

| SR. NO. | GENERATING STN. / STOA | Backing Down Period (in Time Block) | | TARGET DESPATCHE D SCHEDULE | | Backing Down Quantum [Max] in MW [A-B] | REMARK |
|---------|----------------------------|-------------------------------------|----|-----------------------------|-------------------------------|--|--|
| | | FROM | TO | Declared Capacity (A) | Despatched Schedule (Min) (B) | | |
| 1 | TPC U-6 | X | X | X | X | X | UNIT WITHDRAWN ON ECONOMIC SHUTDOWN |
| 2 | JSW TO MSEB FIRM | 1 | 21 | 200 | 140 | 60 | AS PER SYSTEM CONDITION |
| | | 76 | 96 | 200 | 140 | 60 | AS PER SYSTEM CONDITION |
| 3 | TPC U-5 | 1 | 21 | 473 | 292 | 181 | AS PER SYSTEM CONDITION |
| | | 76 | 96 | 473 | 292 | 181 | AS PER SYSTEM CONDITION |
| 4 | TPC U-8 | X | X | X | X | X | SHUT DOWN |
| 5 | DTPS REL U1 AND U2 | 1 | 21 | 461 | 336 | 125 | AS PER SYSTEM CONDITION |
| | | 76 | 96 | 460 | 336 | 124 | AS PER SYSTEM CONDITION |
| 6 | NASHIK U-3,4,5 | 1 | 21 | 320 | 284 | 36 | UNIT-5 SHUT DOWN, B/D AS PER SYSTEM CONDITION |
| | | 80 | 96 | 320 | 284 | 36 | UNIT-5 SHUT DOWN, B/D AS PER SYSTEM CONDITION |
| 7 | BHUSWAL U-2 AND U-3 | X | X | X | X | X | UNIT-2 AND UNIT-3 SHUT DOWN |
| 8 | RATTANINDIA U1 TO U-5 | 1 | 20 | 490 | 344 | 146 | AS PER SYSTEM CONDITION UNIT-2, 3, 5 SHUT DOWN |
| | | 85 | 96 | 490 | 344 | 146 | AS PER SYSTEM CONDITION UNIT-2, 3, 5 SHUT DOWN |
| 9 | PARLEY U-6 AND U-7 | 1 | 20 | 200 | 166 | 34 | AS PER SYSTEM CONDITION UNIT-7 SHUT DOWN |
| | | 85 | 96 | 200 | 166 | 34 | AS PER SYSTEM CONDITION UNIT-7 SHUT DOWN |
| 10 | BHUSWAL U-4 AND U-5 | 1 | 20 | 658 | 644 | 14 | AS PER SYSTEM CONDITION |
| | | 85 | 96 | 658 | 644 | 14 | AS PER SYSTEM CONDITION |
| 11 | VIPL U-1 AND U-2 | 1 | 20 | 572 | 382 | 190 | AS PER SYSTEM CONDITION |
| | | 85 | 96 | 572 | 382 | 190 | AS PER SYSTEM CONDITION |
| 12 | PARALI U-8 | 1 | 20 | X | X | X | D.C. BELOW TECH MIN |
| | | 85 | 96 | X | X | X | D.C. BELOW TECH MIN |
| 13 | KHAPERKHEDA U-1 TO U-4 | 1 | 20 | X | X | X | D.C. BELOW TECH MIN UNIT-1 AND UNIT-2, UNIT-3 SHUT DOWN, |
| | | 85 | 96 | X | X | X | D.C. BELOW TECH MIN UNIT-1 AND UNIT-2, UNIT-3 SHUT DOWN, |
| 14 | PARAS U-3 AND U-4 | 1 | 14 | 460 | 332 | 128 | AS PER SYSTEM CONDITION |
| | | 85 | 96 | 460 | 332 | 128 | AS PER SYSTEM CONDITION |
| 15 | ADANI TIRODA 440 PPA | 1 | 14 | 157.8 | 0 | 157.8 | AS PER SYSTEM CONDITION |
| | | 85 | 96 | 157.8 | 0 | 157.8 | AS PER SYSTEM CONDITION |
| 16 | KORADI U-5,6,7 | X | X | X | X | X | UNIT -5,6,7 SHUTDOWN |
| 17 | ADANI U- 1 (1200+125)MW PP | 1 | 5 | 521 | 432 | 89 | AS PER SYSTEM CONDITION |
| | | 89 | 96 | 521 | 432 | 89 | AS PER SYSTEM CONDITION |
| 18 | ADANI U-4 (1200+125)MW PP | 1 | 5 | 521 | 432 | 89 | AS PER SYSTEM CONDITION |
| | | 89 | 96 | 521 | 432 | 89 | AS PER SYSTEM CONDITION |
| 19 | ADANI U-5 (1200+125)MW PP | X | X | X | X | X | UNIT SHUT DOWN |
| 20 | KHAPERKHEDA U-5 | 1 | 5 | 423 | 335 | 88 | AS PER SYSTEM CONDITION |
| | | 89 | 96 | 423 | 335 | 88 | AS PER SYSTEM CONDITION |
| 21 | CHANDRAPUR U-3 TO U-7 | 1 | 5 | 786 | 656 | 130 | UNIT-3, UNIT-4 UNIT-5 AS PER SYSTEM CONDITION |
| | | 90 | 96 | 786 | 656 | 130 | UNIT-3, UNIT-4 UNIT-5 AS PER SYSTEM CONDITION |
| 22 | KORADI U-8,9,10 | 1 | 5 | 870 | 792 | 78 | UNIT-8 SHUT DOWN, AS PER SYSTEM CONDITION |
| | | 90 | 96 | X | X | X | UNIT-8 SHUT DOWN,D.C. BELOW TECH MIN |
| 23 | JSW U-1 | 1 | 5 | 281 | 200 | 81 | AS PER SYSTEM CONDITION |
| | | 90 | 96 | 281 | 200 | 81 | AS PER SYSTEM CONDITION |
| 24 | CHANDRAPUR U-8 AND U-9 | 90 | 96 | 862 | 658 | 204 | AS PER SYSTEM CONDITION |
| 25 | IEPL TO MSEDCI DA | X | X | X | X | X | NO BACK DOWN unit tripped 23-56hrs |
| 26 | ADANI U-3 | X | X | X | X | X | UNIT SHUT DOWN |
| 27 | ADANI U-2 | X | X | X | X | X | NO BACK DOWN |

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D. RATES REVISED FROM DT. 12TH NOV 2016
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.