

STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE: 23-Jan-14							
SR. NO.	GENERATING STN. / STO A	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	x	x	x	x	x	ECONOMY SHUTDOWN
2	NASIK	1	26	516	425	91	AS PER MOD
		33	34	516	470	46	
		53	56	516	506	10	
		79	96	516	425	91	
3	PARALI-3,4,5	1	24	322	276	46	AS PER MOD
		79	96	322	276	46	
4	BHUSAWAL-2,3	x	x	x	x	x	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
5	BHUSAWAL U4	1	24	400	322	78	AS PER MOD
		79	80	400	322	78	
		82	96	400	322	78	
6	TPC U-5	1	25	473	292	181	AS PER MOD AND DUE TO SYSYEM CONDITION
		80	83	473	292	181	
7	PARLY U-6	1	20	230	166	64	AS PER MOD
		86	96	230	166	64	
8	TPC U-8	x	x	x	x	x	UNIT SHUTDOWN
9	JSW TO RINFRA DA (JSWPTC)	x	x	x	x	x	AS PER MOD
10	PARLY U-7	1	20	230	166	64	AS PER MOD
		88	88	230	166	64	
11	KORADI	x	x	x	x	x	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
12	REL_G	1	19	237	167	70	AS PER MOD
		89	96	477	167	310	
13	KHAPERKHEDA U5	x	x	x	x	x	UNIT SHUTDOWN
14	KHAPER KHEDA U 1 TO 4	1	3	652	572	80	DUE TO SYSTEM CONDITION
		4	19	652	572	80	AS PER MOD
15	BHUSAWAL U5	x	x	x	x	x	DECL BELOW TECH MIN
16	CHANDRAPUR	1	4	1252	1082	170	DUE TO SYSTEM CONDITION
		5	10	1252	1082	170	AS PER MOD
17	INDIA BULL	1	9	245	172	73	DUE TO SYSTEM CONDITION
		10		245	172	73	AS PER MOD
18	PARAS -U3	1	10	230	164	66	DUE TO SYSTEM CONDITION
		1	10	230	214	16	AS PER MOD
19	PARAS U4	1	10	230	220	10	DUE TO SYSTEM CONDITION
20	JSW U-1	1	10	275	200	75	DUE TO SYSTEM CONDITION
21	ADANI U-1	1	4	605	540	65	DUE TO SYSTEM CONDITION

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 MOD rates revised w.e.f 12-Jan.-2013.