

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	DHARIWAL TO TPC_D	X	X	X	X	X	NO TRANSACTION
2	TPC U-5	1	29	470	260	210	AS PER SYSTEM CONDITION #
		33	37	470	260	210	AS PER SYSTEM CONDITION #
3	TPC U-8	5	29	229	126	103	AS PER SYSTEM CONDITION #
		33	37	229	126	103	AS PER SYSTEM CONDITION #
4	DTPS U-1 & U-2	6	29	455	250	205	AS PER SYSTEM CONDITION #
		33	70	455	250	205	AS PER SYSTEM CONDITION #
		75	79	455	250	205	AS PER SYSTEM CONDITION #
5	KORADI U-6 & U-7	1	29	297	206	91	AS PER SYSTEM CONDITION
		34	70	297	206	91	AS PER SYSTEM CONDITION
		75	96	297	206	91	AS PER SYSTEM CONDITION
6	NASIK U-3, U-4 & U-5	1	27	362	204	158	AS PER SYSTEM CONDITION * / U-3 UNDER CASE IV
		34	70	362	204	158	
		75	96	362	204	158	
7	SWPGL to MSEDCL	1	27	240	132	108	AS PER SYSTEM CONDITION
		34	68	240	132	108	AS PER SYSTEM CONDITION
		75	96	240	132	108	AS PER SYSTEM CONDITION
8	BHUSAWAL U-3	1	27	169	104	65	AS PER SYSTEM CONDITION
		34	61	169	104	65	AS PER SYSTEM CONDITION
		78	96	169	104	65	AS PER SYSTEM CONDITION
9	PARALI U-8	1	27	229	122	107	AS PER SYSTEM CONDITION
		34	58	229	122	107	AS PER SYSTEM CONDITION
		78	96	229	122	107	AS PER SYSTEM CONDITION
10	DHARIWAL to MSEDCL (Case-IV)	1	27	185	101.75	83.25	AS PER SYSTEM CONDITION
		34	58	185	101.75	83.25	AS PER SYSTEM CONDITION
		78	96	185	101.75	83.25	AS PER SYSTEM CONDITION
11	PARALI U-6 & U-7	1	27	454	242	212	AS PER SYSTEM CONDITION
		34	58	454	242	212	AS PER SYSTEM CONDITION
		78	96	454	242	212	AS PER SYSTEM CONDITION
12	APML U-1,U-4 & U-5 (PPA440 MW)	1	27	440	0	440	AS PER SYSTEM CONDITION
		34	58	440	0	440	AS PER SYSTEM CONDITION
		83	96	440	0	440	AS PER SYSTEM CONDITION
13	RATTANINDIA U-1 TO U-5	1	26	1200	675	525	AS PER SYSTEM CONDITION
		38	45	1200	675	525	AS PER SYSTEM CONDITION
		84	96	1200	675	525	AS PER SYSTEM CONDITION
14	APML U-1,U-4 & U-5 (PPA 125 MW)	1	24	125	96	29	AS PER SYSTEM CONDITION
		43	45	125	96	29	AS PER SYSTEM CONDITION
15	APML U-1,U-4 & U-5 (PPA 1200 MW)	1	24	1200	921	279	AS PER SYSTEM CONDITION
		43	45	1200	921	279	AS PER SYSTEM CONDITION
16	KHAPERKHEDA U-1 TO U-4	5	23	426	309	117	AS PER SYSTEM CONDITION/ U-1 OUT
17	CHANDRAPUR U-3 TO U-7	9	23	779	502	277	AS PER SYSTEM CONDITION/ U-3,4&7 OUT
18	KORADI U-8 TO U-10	10	19	1255	1023	232	AS PER SYSTEM CONDITION
19	BHUSAWAL U-4 & U-5	11	19	900	518	382	AS PER SYSTEM CONDITION
20	PARAS U-3 & U-4	14	20	421	243	178	AS PER SYSTEM CONDITION
21	KHAPERKHEDA U-5	X	X	X	X	X	NO BACK DOWN
22	CHANDRAPUR U-8 & U-9	X	X	X	X	X	NO BACK DOWN
23	APML U-2 & U-3	X	X	X	X	X	NO BACK DOWN
24	JSW U-1	X	X	X	X	X	UNIT OUT
25	SWPGL to BEST	X	X	X	X	X	NO BACK DOWN

Note :

- 1 MoD stack is prepared as per the clause 33 & 34 of MERC(State Grid Code) 2020.
- 2 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations with ramp are available under "View Schedules" on website.
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.
- 4 * Indicates that back down implemented due to Line loading/system constraints.
- 5 Revised MOD Rates effective from 00:00 hrs of 16th Mar 2021