

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Targat Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	65	506	425	81	AS Per MOD
		74	74	506	485	21	
		79	96	506	425	81	
3	TPC U-8	1	40	235	172	63	AS Per MOD
		84	96				
4	TPC U-5	1	40	473	292	181	AS Per MOD
		85	96	473	325	148	
5	PARALI-6	1	23	200	166	34	AS Per MOD
		25	35				
		37	37	200	181	19	
		44	72	180	166	14	DUE TO SYSTEM CONDITION
6	PARALI 3,4,5	1	22	145	138	7	AS Per MOD
		25	26				
		29	33				
		44	72				DUE TO SYSTEM CONDITION
7	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	PARALI-7	1	21	200	166	34	AS Per MOD
		25	26	200	179	21	
		29	33	200	175	25	
		44	72	200	166	34	DUE TO SYSTEM CONDITION
10	REL G	1	20	479	336	143	AS Per MOD
		21	25				DUE TO SYSTEM CONDITION
		28	35				
11	CHANDRAPUR	1	72	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
12	BHUSAWAL-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
13	INDIABULL TO MSDEL	1	64	245	0	245	DUE TO LINE CONSTARINT#
		65	72	245	172	73	DUE TO SYSTEM CONDITION
14	KHAPERKHEDA-U 1 TO 4	1	20	644	567	77	AS Per MOD
		21	33				DUE TO SYSTEM CONDITION
		44	72				
15	PARAS-3	1	43	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
		44	72	182	164	18	DUE TO SYSTEM CONDITION
16	PARAS-4	1	43	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
		44	72	182	168	14	DUE TO SYSTEM CONDITION

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
17	KHAPERKHEDA-5	X	X	X	X	X	UNIT UNDER OUTAGE
18	JSW U 1	1	3	275	200	75	DUE TO SYSTEM CONDITION
		4	19				AS Per MOD
		20	33				DUE TO SYSTEM CONDITION
		45	72				
19	AMNEPL TO REL	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
20	APML U 2 TO MSEDCL	1	33	617	432	185	DUE TO SYSTEM CONDITION
		46	72				
21	APML U 3 TO MSEDCL	1	33	617	432	185	DUE TO SYSTEM CONDITION
		46	72				
22	WPCL TO REL	55	72	196	160	36	DUE TO SYSTEM CONDITION
TPC U 8 ,U 5 IN BLK(41-72) & REL G IN BLK(36-72) BACKING DOWN NOT IMPLEMENTED DUE TO LINE LOADING CONSTRAINT IN MUMBAI SYSTEM.							
# INDIABULL GEN SCH.RESTRICTED TO BE ZERO DUE TO TRIPPING OF 400KV KORADI-INDIABULL & KORADI-AKOLA LINE							

Note :

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- MOD rates revised w.e.f 12-Sep.-2013.