

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
2	NASIK U-3, U-4 & U-5	1	72	177	102	75	AS PER SYSTEM CONDITION / U-3 UNDER
		80	96	177	102	75	ZERO SCHEDULE & U-5 UNDER CASE-IV
3	DTPS U-1 & U-2	33	42	455	250	205	AS PER SYSTEM CONDITION #
		80	96	455	250	205	AS PER SYSTEM CONDITION #
4	TPC U-5	X	X	X	X	X	NO BACK DOWN #
6	RATTANINDIA U-1 TO U-5	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
7	TPC U-8	X	X	X	X	X	NO BACK DOWN #
8	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
9	PARALI U-6 & U-7	1	72	227	121	106	AS PER SYSTEM CONDITION/ U-7 UNDER
		80	96	227	121	106	ZERO SCHEDULE
10	APML U-1,U-4 & U-5 (PPA440 MW)	1	25	411	0	411	AS PER SYSTEM CONDITION
		33	68	411	0	411	AS PER SYSTEM CONDITION
		86	96	411	0	411	AS PER SYSTEM CONDITION
5	JSWEL TO AEML_DA	1	25	169	92.95	76.05	AS PER SYSTEM CONDITION
		37	68	169	92.95	76.05	AS PER SYSTEM CONDITION
		89	96	169	92.95	76.05	AS PER SYSTEM CONDITION
11	JSWEL TO AEML_DA	1	25	365	200.75	164.25	AS PER SYSTEM CONDITION
		37	68	365	200.75	164.25	AS PER SYSTEM CONDITION
		89	96	365	200.75	164.25	AS PER SYSTEM CONDITION
12	DHARIWAL TO AEML_DA	1	25	85	46.75	38.25	AS PER SYSTEM CONDITION
		37	68	85	46.75	38.25	AS PER SYSTEM CONDITION
		89	96	85	46.75	38.25	AS PER SYSTEM CONDITION
13	SWPGL to MSEDCL	1	25	240	132	108	AS PER SYSTEM CONDITION
		37	68	240	132	108	AS PER SYSTEM CONDITION
		93	96	240	132	108	AS PER SYSTEM CONDITION
14	APML U-1,U-4 & U-5 (PPA1200MW,125 MW)	1	21	1239	1017	222	AS PER SYSTEM CONDITION
		37	64	1239	1017	222	AS PER SYSTEM CONDITION
		96	96	1239	1017	222	AS PER SYSTEM CONDITION
15	PARALI U-8	1	21	229	122	107	AS PER SYSTEM CONDITION
		41	64	229	122	107	AS PER SYSTEM CONDITION
		96	96	229	122	107	AS PER SYSTEM CONDITION
16	DHARIWAL to MSEDCL (Case-IV)	1	20	185	101.75	83.25	AS PER SYSTEM CONDITION
		41	64	185	101.75	83.25	AS PER SYSTEM CONDITION
17	BHUSAWAL U-4 & U-5	1	20	940	518	422	AS PER SYSTEM CONDITION
		41	62	940	518	422	AS PER SYSTEM CONDITION
18	KHAPERKHEDA U-1 TO U-4	2	19	672	413	259	AS PER SYSTEM CONDITION
		42	57	672	413	259	AS PER SYSTEM CONDITION
19	KORADI U-8 TO U-10	2	19	1410	1023	387	AS PER SYSTEM CONDITION
		44	56	1410	1023	387	AS PER SYSTEM CONDITION
20	CHANDRAPUR U-3 TO U-7	4	18	1052	712	340	AS PER SYSTEM CONDITION/ U-7 OUT
		44	56	1052	712	340	AS PER SYSTEM CONDITION/ U-7 OUT
21	KHAPERKHEDA U-5	X	X	X	X	X	UNIT OUT
22	JSW U-1	5	18	283	160	123	AS PER SYSTEM CONDITION
		44	48	283	160	123	AS PER SYSTEM CONDITION
23	CHANDRAPUR U-8 & U-9	X	X	X	X	X	NO BACK DOWN
24	PARAS U-3 & U-4	X	X	X	X	X	NO BACK DOWN
25	APML U-2 & U-3	X	X	X	X	X	NO BACK DOWN
26	SWPGL to BEST	X	X	X	X	X	NO BACK DOWN

Note :

- 1 MoD stack is prepared as per the clause 33 & 34 of MERC(State Grid Code) 2020.
- 2 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch.
- Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.
- 4 * Indicates that back down implemented due to Line loading/system constraints.
- 5 Revised MOD Rates effective from 00:00 hrs of 22nd Oct 2020