

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							24-Jan-17
SR. NO.	GENERATING STN. / STO	Backing Down Period (in Time)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT SHUTDOWN
2	REL DAHANU U 1&2	1	26	467	336	131	AS PER SYSTEM CONDITION
		72	96	467	336	131	AS PER SYSTEM CONDITION
3	NASIK	1	26	354	283	71	UNIT-3 W/DN FOR ZERO SCHEDULE BY MSEDCL, B/D AS PER SYSTEM CONDITION
		72	96	354	283	71	UNIT-3 W/DN FOR ZERO SCHEDULE BY MSEDCL, B/D AS PER SYSTEM CONDITION
4	TPC U8	1	26	235	187	48	AS PER SYSTEM CONDITION
		80	96	235	187	48	AS PER SYSTEM CONDITION
5	TPCU5	X	X	X	X	X	UNIT SHUT DOWN
6	RATTANINDIA U1,2,3,4,5	X	X	X	X	X	UNIT-1,2,3,4,5 W/DNFOR ZERO SCHEDULE BY MSEDCL
7	BHUSWAL 2,3	X	X	X	X	X	UNIT-2 AND UNIT-3 W/DN FOR ZERO SCHEDULE
8	KORADI U-5 TO U-7	X	X	X	X	X	UNIT-6 SHUT DOWN UNIT-5 SHUT DOWN UNIT-7 SHUT DOWN
9	KHAPERKHEDA U1 TO U4	1	25	723	572	151	AS PER SYSTEM CONDITION
		81	96	723	572	151	UNIT-1 TRIPPED AT 8:13HRS AND SYN. 14:03HRSAS PER SYSTEM CONDITION
10	PARLYU-8	X	X	X	X	X	UNIT SHUT DOWN
11	KHAPERKHEDA U-5	1	25	478	335	143	AS PER SYSTEM CONDITION
		81	86	478	335	143	UNIT-5 TRIPPED AT 21:31HRS B/D AS PER SYSTEM CONDITION
		87	96	X	X	X	UNIT-5 TRIPPED AT 21:31HRS B/D AS PER SYSTEM CONDITION
12	BHUSWAL U-4AND U-5	1	23	940	644	296	AS PER SYSTEM CONDITION
		81	96	940	644	296	AS PER SYSTEM CONDITION
13	PARAS U-3 AND U-4	X	X	X	X	X	UNIT-3 and UNIT-4 SHUT DOWN AS PER SYSTEM CONDITION
14	PARLEY U-6 AND U-7	1	23	458	332	126	, B/D AS PER SYSTEM CONDITION
		81	96	458	332	126	B/D AS PER SYSTEM CONDITION
15	VIPL U1,2	1	23	273	191	82	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
		81	96	273	191	82	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
16	ADANI U1	X	X	X	X	X	UNIT-1SHUT DOWN
17	ADANI U4	1	23	X	X	X	D.C. TECH MIN
		89	96	X	X	X	D.C. TECH MIN
18	ADANI U5	1	23	X	X	X	D.C. TECH MIN
		89	96	X	X	X	D.C. TECH MIN
19	KORADI U8 ,U9,10	1	13	1250	864	386	UNIT-8 SHUT DOWN ,B/D AS PER SYSTEM CONDITION
		14	17	625	432	193	UNIT-8 SHUT DOWN , UNIT-9 TRIPPED AT 3:11HRSB/D AS PER SYSTEM CONDITION
		89	96	839	646	193	UNIT-8 SHUT DOWN , UNIT-9 TRIPPED AT 3:11HRSAND SYN. 5:56HRSB/D AS PER SYSTEM CONDITION
20	CHANDRAPURU3 TO U7	1	10	1210	954	256	UNIT-6 SHUT DOWN B/DAS PER SYSTEM CONDITION
		11	17	1400	1154	246	UNIT-6 SYN. 3:04HRS B/DAS PER SYSTEM CONDITION
		91	96	1210	954	256	UNIT-6 TRIPPED 6:29HRS. UNIT-6 TRIPPED AT 23:55HRS B/DAS PER SYSTEM CONDITION
21	CHANDRAPUR U8AND U9	1	17	948	658	290	B/DAS PER SYSTEM CONDITION
		91	96	948	658	290	B/DAS PER SYSTEM CONDITION
22	ADANI UNIT-2	9	17	532	432	100	AS PER SYSTEM CONDITION
23	ADANI U-3	9	17	532	432	100	AS PER SYSTEM CONDITION
24	JSW U-1	X	X	X	X	X	UNIT SHUT DOWN

X

NOTE:

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- M.O.D RATES R1 EFFECTIVE FROM 21 JAN2017
- # Indicates that back down withdrawn due to Line loading/system constraints.