

STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:						24-Feb-14	
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	x	x	x	x	x	ECONOMY SHUTDOWN
2	NASIK	1	29	516	425	91	AS PER MOD
		70	75	516	425	91	
		84		516	494	22	
		86	96	516	425	91	
3	BHUSAWAL-2,3	x	x	x	x	x	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
4	TPC U-5	1	28	473	292	181	AS PER MOD
		84	96	473	292	181	
5	TPC U-8	x	x	x	x	x	UNIT SHUTDOWN
6	PARALI-3,4,5	1	24	292	276	16	AS PER MOD
		72	73	292	276	16	
		88	96	292	276	16	
7	JSW TO RINFRA DA (JSWPTC)	72	73	70	49	21	AS PER MOD
		88		93	65	28	
8	KORADI	x	x	x	x	x	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	DHARIWAL	72		220	154	66	(VARIABLE SCH - TECH MIN 150 MW) AS PER MOD
		88		220	154	66	
		89		185	150	35	
10	KHAPERKHEDA U5	1	23	475	335	140	AS PER MOD
		72	72	475	367	108	
		88	96	475	335	140	
11	PARLY U-6	x	x	x	x	x	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
12	BHUSAWAL U4	1	22	465	322	143	AS PER MOD
		89		465	458	7	
		94		465	452	13	
13	REL_G	1	1	478	336	142	DUE TO SYSTEM CONDITION
		2	22	478	336	142	AS PER MOD
		93	96	478	336	142	DUE TO SYSTEM CONDITION
14	PARLY U-7	x	x	x	x	x	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
15	KHAPER KHEDA U 1 TO 4	1	2	499	431	68	DUE TO SYSTEM CONDITION
		3	21	499	431	68	AS PER MOD
		94	96	499	431	68	DUE TO SYSTEM CONDITION
16	BHUSAWAL U5	x	x	x	x	x	DECL BELOW TECH MIN
17	CHANDRAPUR	1	3	1523	1357	166	DUE TO SYSTEM CONDITION
		4	21	1523	1357	166	AS PER MOD
		94	96	1523	1357	166	DUE TO SYSTEM CONDITION
18	INDIA BULL	1	4	245	172	73	DUE TO SYSTEM CONDITION
		5	20	245	172	73	AS PER MOD
		94	96	245	172	73	DUE TO SYSTEM CONDITION

19	PARAS -U3	1	5	230	164	66	DUE TO SYSTEM CONDITION
		6	19	230	164	66	AS PER MOD
		94	96	230	164	66	DUE TO SYSTEM CONDITION
20	PARAS U4	1	5	230	168	62	DUE TO SYSTEM CONDITION
		6	18	230	168	62	AS PER MOD
		94	96	230	168	62	DUE TO SYSTEM CONDITION
21	ADANI U-1	x	x	x	x	x	UNIT SHUTDOWN
22	JSW U-1	6	17	275	264	11	DUE TO SYSTEM CONDITION
23	AMNEPL TO RINFRA	x	x	x	x	x	NO SCHEDULE
24	JSW TO RINFRA (RETL) (55 MW)	x	x	x	x	x	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
25	ADANI U-2 AND U-3	6	17	1246	1080	166	DUE TO SYSTEM CONDITION

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 MOD rates revised w.e.f 12-Feb.-2014.