

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	34	546	425	121	DUE TO SYSTEM CONDITION
		37	76	546			
		82	87	546	514	32	
		90	96	546	433	113	
3	TPC U-8	1	29	235	172	63	AS Per MOD
		50	56				
		65	71				
4	TPC U-5	1	28	473	292	181	AS Per MOD
		66	74				
5	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
6	PARALI 3,4,5	X	X	X	X	X	NO SCHEDULE
7	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	REL G	2	21	479	336	143	AS Per MOD
9	BHUSAWAL-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
10	PARALI-7	10	20	200	166	34	AS Per MOD
11	PARALI-6	10	20	200	166	34	AS Per MOD
12	INDIABULL TO MSSEDCL	10	20	245	172	73	AS Per MOD
13	KHAPERKHEDA-5	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
14	KHAPERKHEDA-U 1 TO 4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
15	CHANDRAPUR	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
16	PARAS-3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
17	PARAS-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
18	JSW U 1	X	X	X	X	X	UNIT W/DN
19	AMNEPL TO REL	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
20	APML U 2 TO MSSEDCL	70	78	617	460	157	DUE TO EMERGENCY OUTAGE ON 400 KV WARDHA- WARORA CKT-1
21	APML U 3 TO MSSEDCL	70	78	617	460	157	DUE TO EMERGENCY OUTAGE ON 400 KV WARDHA- WARORA CKT-1

**Note :**

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 13-Aug.-2013.