

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							24-Aug-16
SR. NO.	GENERATING STN. / STO A	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT SHUTDOWN
2	NASIK	1	26	354	284	70	AS PER SYSTEM CONDITION :UNIT-5 ZERO SCHEDULE BY MSEDCL
		68	96	354	284	70	AS PER SYSTEM CONDITION :UNIT-5 ZERO SCHEDULE BY MSEDCL
3	BHUSWAL U 2,3	X	X	x	x	x	MSEDCL W/DN UNIT-3 FOR ZERO SCHEDULE AND UNIT-2SHUT DOWN
4	REL DAHANU U 1&2	1	26	466	336	130	AS PER SYSTEM CONDITION
		68	75	466	336	130	AS PER SYSTEM CONDITION
		81	96	466	336	130	AS PER SYSTEM CONDITION
5	RATAN INDIA U-1,2,3,4,5.	x	x	x	x	x	MSEDCL W/DN UNIT- 1 TO 5 FOR ZERO SCHEDULE
6	TPC U-5	1	21	473	292	181	AS PER SYSTEM CONDITION
		68	75	473	292	181	AS PER SYSTEM CONDITION
		82	96	473	292	181	AS PER SYSTEM CONDITION
7	TPC U-8	1	21	235	187	48	AS PER SYSTEM CONDITION
		68	75	235	187	48	AS PER SYSTEM CONDITION
		82	96	235	187	48	AS PER SYSTEM CONDITION
8	BHUSWAL U -4 AND U-5	1	18	470	322	148	UNIT-4 ZERO SCHEDULE W/DN. BY MSEDCL UNIT-4 SYN.AT4:45HRS B/D AS PER SYSTEM CONDITION
		19	21	570	422	148	UNIT-4 SYN. B/D AS PER SYSTEM CONDITION
		68	75	940	644	296	AS PER SYSTEM CONDITION
		82	96	940	644	296	AS PER SYSTEM CONDITION
9	VIPL U1&2	1	21	546	382	164	AS PER SYSTEM CONDITION
		69	75	546	420	126	AS PER SYSTEM CONDITION
		82	96	546	382	164	AS PER SYSTEM CONDITION
10	KORADI U-5 TO U-7	1	20	X	X	X	UNIT-6 SHUT DOWN UNIT-7 D.C. BELOW TECH MIN. AND UNIT-5 ZERO SCHEDULE WITHDRAWN BY MSEDCL BUT UNIT SYN . DELAYED DUE TO TECHNICAL PROBLEM
		69	74	X	X	X	UNIT-6 SHUT DOWN UNIT-7 D.C. BELOW TECH MIN. AND UNIT-5 ZERO SCHEDULE WITHDRAWN BY MSEDCL BUT UNIT SYN . DELAYED DUE TO TECHNICAL PROBLEM
		82	96	X	X	X	UNIT-6 AND ANDUNIT-7 D.C. BELOW TECH MIN.,UNIT-5SYN. AT 21:02HRS BUT D.C. BELOW TECH MIN
11	KHAPERKhedA U1 TO U4	1	20	552	431	121	AS PER SYSTEM CONDITION UNIT-4 AOH
		69	74	552	431	121	AS PER SYSTEM CONDITION UNIT-4 AOH
		82	96	552	431	121	AS PER SYSTEM CONDITION UNIT-4 AOH
12	ADANI U-1	5	20	500	432	68	AS PER SYSTEM CONDITION
		69	74	485	432	53	AS PER SYSTEM CONDITION
		82	96	485	432	53	AS PER SYSTEM CONDITION
13	ADANI U-4	x	x	X	X	X	SHUT DOWN
14	ADANI U-5	5	20	515	432	83	AS PER SYSTEM CONDITION
		69	74	515	432	83	AS PER SYSTEM CONDITION
		82	96	515	432	83	AS PER SYSTEM CONDITION
15	PARAS U-3 AND U-4	7	20	460	332	128	AS PER SYSTEM CONDITION
		69	74	460	332	128	AS PER SYSTEM CONDITION
		89	96	460	332	128	AS PER SYSTEM CONDITION
16	CHANDRAPUR U-3 to 7	7	20	1402	1136	266	UNIT-4 SHUT DOWN B/D AS PER SYSTEM CONDITION
		71	74	1402	1136	266	UNIT-4 SHUT DOWN B/D AS PER SYSTEM CONDITION
		89	96	1402	1136	266	UNIT-4 SHUT DOWN B/D AS PER SYSTEM CONDITION
17	KORADI U-8	7	20	500	432	68	AS PER SYSTEM CONDITION
		72	74	470	432	38	AS PER SYSTEM CONDITION
		92	96	495	432	63	AS PER SYSTEM CONDITION
18	CHANDRAPUR U-8	7	20	423	329	94	AS PER SYSTEM CONDITION
		72	74	423	329	94	AS PER SYSTEM CONDITION
		93	96	388	329	59	AS PER SYSTEM CONDITION
19	KHAPERKhedA U-5	7	20	475	335	140	AS PER SYSTEM CONDITION
		72	74	475	335	140	AS PER SYSTEM CONDITION

		93	96	475	335	140	AS PER SYSTEM CONDITION
20	ADANI U-3	7	11	623	575	48	AS PER SYSTEM CONDITION
		72	74	600	530	70	AS PER SYSTEM CONDITION
21	ADANI U-2	7	11	623	570	53	AS PER SYSTEM CONDITION
		72	74	615	565	50	AS PER SYSTEM CONDITION
22	JSW U-1	X	X	X	X	X	NO BACK DOWN
X							

1

Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backindown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2

M.O.D. RATES REVISED FROM 12 TH OF AUG 2016

3

# Indicates that back down withdrawn due to Line loading/system constraints.