

## STATEMENT OF GENERATOR / STOA SCHEDULES (EX\_BUS) BACKED DOWN FOR THE DATE:

24-Nov-12

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	22	483	145	338	AS Per MOD
		23	26	483	230	253	
		27	37	483	345	138	
		87	92	483	300	183	
		93	96	483	180	303	
2	TPC U-5	x	x	x	x	x	UNIT TRIPPED ON BTL
3	JSW U4 TO MSEDCL	x	x	x	x	x	MSEDCL REQUIREMENT OF TECHNICAL MINIMUM
4	JSW U2 TO MSEDCL	x	x	x	x	x	MSEDCL REQUIREMENT OF TECHNICAL MINIMUM
5	NASIK	6	20	x	x	x	#
6	TPC U-8	1	1	235	200	35	AS Per MOD
		8	21	X	X	X	#
		92	96	235	180	55	DUE TO SYSTEM CONDITION

# SCHEDULE WAS REDUCED AS PER MOD. BACKDOWN WAS WITHDRAWN DUE TO REAL TIME SYSTEM CONDITIONS.

**Note :**

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 11-Nov-2012.