

STATEMENT OF GENERATOR / STOA SCHEDULES (EX\_BUS) BACKED DOWN FOR THE DATE:

25-Jan-12

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	1	20	483	145	338	AS Per MOD
		94	96	483	255	228	
2	JSW U-4 (STOA)	X	X	X	X	X	MSEDCL HAS CURTAILED POWER FROM 00:00 to 05:00 hrs & 21:00 to 24:00 to 190 MW (TECHNICAL MINIMUM)
3	ABHIJIT TO MSEDCL (STOA)	X	X	X	X	X	MSEDCL HAS CURTAILED POWER FROM 52 TO 35MW ( 00:00 TO 05:00 HRS & 21:00 TO 24:00 Hrs)
4	TPC U-5	X	X	X	X	X	UNDER OUTAGE
5	TPC U-8	5	21	230	160	70	AS Per MOD
6	JSW U-2 (STOA)	8	20	275	190	85	AS Per MOD
7	NASHIK	X	X	X	X	X	
8	REL_G	X	X	X	X	X	

# DUE TO SYSTEM CONDITION, NASIK & REL\_G BACKINGDOWN WAS WITHDRAWN.

*Note :*

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 From 19-1-2012, JSW Unit-3 is having CPP transaction with JSW ISPAT for 220 MW RTC, part of the balance power is sold in IEX.