

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

25-May-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	96	483	145	338	AS PER MOD
2	NASIK	1	21	X	X	X	#
		21	68	516	425	91	AS PER MOD
		70	96	516	425	91	
3	BHUSAWAL 2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
4	VIPL TO MSEDCL	3	20	X	X	X	#
		21	26	85	59.5	25.5	AS PER MOD
		41	56				
		68	96				
5	JSW U-2,4-MSEDCL	4	20	X	X	X	#
		21	27	250	175	75	AS PER MOD
		36	57	X	X	X	DC REVISED BY LM CELL
		68	96				
6	REL G	8	20	X	X	X	#
		21	27	475	336	139	AS PER MOD
		52	56	475	387	88	
		72	79	475	336	139	
		82	86	475	464	11	
7	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	TPC U-5	9	20	X	X	X	#
		21	34	473	292	181	AS PER MOD
		70	80				
9	TPC U-8	12	20	X	X	X	#
		21	31	235	180	55	AS PER MOD
		74	77	235	172	63	

SCHEDULE WAS REDUCED AS PER MOD. BUT, BACKDOWN WAS WITHDRAWN DUE TO REAL TIME SYSTEM CONDITIONS.

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-May-2013.