

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							25-May-16
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min)		
1	TPC U-6	x	x	X	X	X	UNIT SHUTDOWN
2	NASIK	33	42	561	425	136	AS PER SYSTEM CONDITION
		43	93	X	X	X	#
3	BHUSWAL U 2,3	33	93	304	287	17	AS PER SYSTEM CONDITION
4	RATTAN INDIA U:1,2 ,3, 4,5	33	93	245	172	73	MSEDCL W/D UNIT-4 ,5,1,3 FOR ZERO SCHEDULE , B/D AS PER SYSTEM CONDITION
5	KORADI U5 TO U7	33	93	171	155	16	MSEDCL W/D UNIT- 5 FOR ZERO SCHEDULE , B/D AS PER SYSTEM CONDITION
6	REL DAHANU U 1&2	33	93	X	X	X	#
7	TPC U-5	33	93	x	x	x	#
8	TPC U-8	33	93	x	x	x	#
9	BHUSWAL U-4 & 5	33	93	940	644	296	AS PER SYSTEM CONDITION
10	VIPL U1&2	33	93	546	382	164	AS PER SYSTEM CONDITION
11	KHAPERKHEDA U1 TO U4	47	93	742	572	170	AS PER SYSTEM CONDITION
12	KORADI U-8	47	77	620	432	188	AS PER SYSTEM CONDITION
13	CHANDRAPUR	47	77	1734	1282	452	AS PER SYSTEM CONDITION
14	PARAS U-3 AND U-4	66	77	460	332	128	AS PER SYSTEM CONDITION
15	KHAPERKHEDA U-5	66	77	475	335	140	AS PER SYSTEM CONDITION
16	ADANI U-1	x	x	x	x	x	SHUT DOWN
17	ADANI U-4	x	x	x	x	x	NO BACK DOWN
18	ADANI U-5	x	x	x	x	x	UNIT SHUTDOWN
19	JSW U-1	x	x	x	x	x	NO BACK DOWN
20	ADANI U-2	x	x	x	x	x	UNIT SHUTDOWN
21	ADANI U-3	x	x	x	x	x	UNIT SHUTDOWN

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D. RATES REVISED FROM 12TH OF MAY 2016
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.