

SR. NO.	GENERATING STN. / STOA	Backing Down Period (n Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	DTPS REL U-1 AND U-2	1	26	468	336	122	AS PER SYSTEM CONDITION
		37	77	468	336	122	AS PER SYSTEM CONDITION
		82	96	468	336	122	AS PER SYSTEM CONDITION
2	TPC U-5	1	26	473	292	181	AS PER SYSTEM CONDITION
		37	77	473	292	181	AS PER SYSTEM CONDITION
		82	96	473	292	181	AS PER SYSTEM CONDITION
3	TPC U-8	1	26	204	187	17	AS PER SYSTEM CONDITION
		37	77	204	187	17	AS PER SYSTEM CONDITION
		82	96	204	187	17	AS PER SYSTEM CONDITION
4	NASIK U-3,4 AND 5	1	24	167	142	25	AS PER SYSTEM CONDITION unit-5 withdrawn for zero schedule by mseedclat08hrs of 12/07/2018
		37	77	167	142	25	AS PER SYSTEM CONDITION unit-5 withdrawn for zero schedule by mseedclat08hrs of 12/07/2018
		82	96	167	142	25	AS PER SYSTEM CONDITION unit-5 withdrawn for zero schedule by mseedclat08hrs of 12/07/2018
5	BHUSWAL U-3	X	X	X	X	X	UNIT SHUT DOWN
6	RATTANIKHEDA U-1 TO U-5	X	X	X	X	X	UNIT-2 AND UNIT-5 WITHDRAWN FOR ZERO SCHEDULE BY MSEDCL AT 08HRS OF 12/07/2018. UNIT-3 WITHDRAWN FOR ZERO SCHEDULE BY MSEDCL AT 08HRS OF 26/06/2018. UNIT-1 AND UNIT-4 SHUT DOWN
7	PARALI U-6&U-7	X	X	X	X	X	UNIT-7, UNIT-6 WITHDRAWN FOR ZERO SCHEDULE BY MSEDCL
8	BHUSWAL U-4 AND U-5	1	21	470	322	148	AS PER SYSTEM CONDITION UNIT-4 SHUT DOWN
		39	77	470	322	148	AS PER SYSTEM CONDITION UNIT-4 SHUT DOWN
		83	86	470	322	148	AS PER SYSTEM CONDITION UNIT-4 SHUT DOWN
		90	96	470	322	148	AS PER SYSTEM CONDITION UNIT-4 SHUT DOWN
9	IEPL TO MSEDCL	X	X	X	X	X	UNIT SHUT DOWN
10	DHARWAL TO MSEDCL	X	X	X	X	X	UNIT SHUT DOWN
11	KORADI U-6&U-7	X	X	X	X	X	UNIT-6 AND UNIT-7 SHUT DOWN
12	VPL U1 &2	1	20	572	382	190	AS PER SYSTEM CONDITION
		43	77	572	382	190	AS PER SYSTEM CONDITION
		83	96	572	415	157	AS PER SYSTEM CONDITION
		92	96	572	548	24	AS PER SYSTEM CONDITION
13	KORADI U-8,9,10	1	20	1042	864	178	D.C. BELOW TECH MIN. UNIT-8 SHUT DOWN
		43	74	1089	864	225	D.C. BELOW TECH MIN. UNIT-8 SHUT DOWN
		83	86	1089	864	225	D.C. BELOW TECH MIN. UNIT-8 SHUT DOWN
		96	96	1089	864	225	D.C. BELOW TECH MIN. UNIT-8 SHUT DOWN
14	PARAS U-3 AND U-4	1	20	402	332	70	AS PER SYSTEM CONDITION
		43	74	402	332	70	AS PER SYSTEM CONDITION
		83	86	402	332	70	AS PER SYSTEM CONDITION
		96	96	402	332	70	AS PER SYSTEM CONDITION
15	ADANI (THRODA 640MW PPA) U1,&5	1	20	X	X	X	D.C. ZERO
		43	73	X	X	X	D.C. ZERO
16	KHAPERKHEDA U-1 TO U-4	1	20	445	X	X	D.C. BELOW TECH MIN AS PER SYSTEM CONDITION
		43	73	378	X	X	D.C. BELOW TECH MIN AS PER SYSTEM CONDITION
17	KHAPERKHEDA U-5	X	X	X	X	X	UNIT SHUT DOWN
18	ADANI U-1(1200+125)MW PP	1	20	432	X	X	D.C. TECH MIN
		43	73	432	X	X	D.C. TECH MIN
19	ADANI U-4(1200+125)MW PP	1	20	432	X	X	D.C. TECH MIN
		43	73	432	X	X	D.C. TECH MIN
20	ADANI U-5(1200+125)MW PP	1	20	432	X	X	D.C. TECH MIN
		43	73	432	X	X	D.C. TECH MIN
21	CHANDRAPUR U-3 TO U-7	1	20	X	X	X	UNIT-3 AND UNIT-4 SHUT DOWN D.C. BELOW TECH MIN
		46	63	X	X	X	UNIT-3 AND UNIT-4 SHUT DOWN D.C. BELOW TECH MIN
22	PARALI U-8	1	20	229	166	63	AS PER SYSTEM CONDITION
		50	63	229	166	63	AS PER SYSTEM CONDITION
23	JSW U-1	1	19	X	X	X	D.C. BELOW TECH MIN
		50	63	X	X	X	D.C. BELOW TECH MIN
24	CHANDRAPUR U-8 AND U-9	1	18	474	332	142	AS PER SYSTEM CONDITION MIN UNIT-9 SHUT DOWN
		51	63	445	332	113	AS PER SYSTEM CONDITION MIN UNIT-9 SHUT DOWN
25	ADANI U-2	51	52	432	X	X	D.C. TECH MIN
26	ADANI U-3	51	52	432	X	X	D.C. TECH MIN

## Note:

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.C.D. RATES REVISED FROM 07.07/14 JULY 2018

3 # Indicates that back down withdrawn due to Line loading/system constraints.