

STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:

25/07/2021

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-5	1	57	445	260	185	AS PER SYSTEM CONDITION #
		61	96	445	260	185	AS PER SYSTEM CONDITION #
2	TPC U-8	1	53	229	126	103	AS PER SYSTEM CONDITION #
		62	96	229	126	103	AS PER SYSTEM CONDITION #
3	DTPS U-1 & U-2	1	96	455	250	205	AS PER SYSTEM CONDITION
4	NASIK U-3, U-4 & U-5	1	33	185	102	83	AS PER SYSTEM CONDITION #/ U-3 UNDER
		84	96	185	102	83	CASE IV & U-4 UNDER ZERO SCHEDULE
5	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
6	PARALI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
7	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
8	PARALI U-8	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
9	KHAPERKHEDA U-1 TO U-4	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
10	PARAS U-3 & U-4	1	96	227	122	105	AS PER SYSTEM CONDITION / U-3 OUT
11	SWPGL to MSEDCL	X	X	X	X	X	PPA UNDER ZERO SCHEDULE
12	BHUSAWAL U-4 & U-5	1	80	470	259	211	AS PER SYSTEM CONDITION / U-5 UNDER
		84	96	470	259	211	ZERO SCHEDULE
13	RATTANINDIA U-1 TO U-5	1	22	980	540	440	AS PER SYSTEM CONDITION/ U-3 OUT
		29	72	980	540	440	AS PER SYSTEM CONDITION/ U-3 OUT
		84	96	980	540	440	AS PER SYSTEM CONDITION/ U-3 OUT
		1	21	426	0	426	AS PER SYSTEM CONDITION
14	APML U-1,U-4 & U-5 (PPA 440 MW)	29	72	426	0	426	AS PER SYSTEM CONDITION
		84	96	426	0	426	AS PER SYSTEM CONDITION
		1	20	1360	963	397	AS PER SYSTEM CONDITION
15	CHANDRAPUR U-3 TO U-7	39	72	1360	963	397	AS PER SYSTEM CONDITION
		93	96	1360	963	397	AS PER SYSTEM CONDITION
		1	20	185	101.75	83.25	AS PER SYSTEM CONDITION
16	DHARIWAL to MSEDCL (Case-IV)	39	72	185	101.75	83.25	AS PER SYSTEM CONDITION
		93	96	185	101.75	83.25	AS PER SYSTEM CONDITION
		1	19	121	96	25	AS PER SYSTEM CONDITION
17	APML U-1,U-4 & U-5 (PPA 125 MW)	41	71	121	96	25	AS PER SYSTEM CONDITION
		95	96	121	96	25	AS PER SYSTEM CONDITION
		1	19	1161	921	240	AS PER SYSTEM CONDITION
18	APML U-1,U-4 & U-5 (PPA 1200 MW)	41	71	1161	921	240	AS PER SYSTEM CONDITION
		95	96	1161	921	240	AS PER SYSTEM CONDITION
		1	18	470	256	214	AS PER SYSTEM CONDITION
19	KHAPERKHEDA U-5	41	71	470	256	214	AS PER SYSTEM CONDITION
		96	96	470	256	214	AS PER SYSTEM CONDITION
		1	18	423	259	164	AS PER SYSTEM CONDITION/ U-9 OUT
20	CHANDRAPUR U-8 & U-9	41	71	423	259	164	AS PER SYSTEM CONDITION/ U-9 OUT
		96	96	423	259	164	AS PER SYSTEM CONDITION/ U-9 OUT
		41	70	1246	678	568	AS PER SYSTEM CONDITION
21	APML U-2 & U-3	41	70	1246	678	568	AS PER SYSTEM CONDITION
22	KORADI U-8 TO U-10	42	70	X	X	X	DC TECH MIN
23	JSW U-1	42	70	290	160	130	AS PER SYSTEM CONDITION
24	SWPGL to BEST	42	70	100	66	34	AS PER SYSTEM CONDITION

Note :

- MoD stack is prepared as per the clause 33 & 34 of MERC(State Grid Code) 2020.
- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations with ramp are available under "View Schedules" on website.
- # Indicates that back down withdrawn due to Line loading/system constraints.
- * Indicates that back down implemented due to Line loading/system constraints.
- Revised MOD Rates effective from 00:00 hrs of 16th July 2021
- Nasik U-5 & Paras U-4 kept on bar due to Line loading/system constraints.