

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	63	506	425	81	AS Per MOD
		68	68	506	495	11	
		69	74	506	425	81	DUE TO SYSTEM CONDITION
		76	86	506	488	18	AS Per MOD
		89	96	506	425	81	
3	TPC U-8	1	39	235	172	63	AS Per MOD
		45	50	235	210	25	
		89	96	235	172	63	
4	TPC U-5	1	39	473	292	181	AS Per MOD
		91	96	473	370	103	
5	PARALI-6	1	33	200	166	34	AS Per MOD
		69	74				DUE TO SYSTEM CONDITION
6	PARALI 3,4,5	1	31	290	276	14	AS Per MOD
		69	74	260	253	7	DUE TO SYSTEM CONDITION
7	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	PARALI-7	1	31	200	166	34	AS Per MOD
		69	74				DUE TO SYSTEM CONDITION
10	REL G	1	30	479	336	143	AS Per MOD
11	CHANDRAPUR	1	4	1123	1067	56	DUE TO SYSTEM CONDITION
		5	20				AS Per MOD
		69	74				DUE TO SYSTEM CONDITION
12	BHUSAWAL-4	1	4	360	322	38	DUE TO SYSTEM CONDITION
		5	20				AS Per MOD
		69	74	X	X	X	DC REVISED TO BELOW TECHNICAL MINIMUM DUE TO PCQ
13	INDIABULL TO MSEDCL	1	5	245	172	73	DUE TO SYSTEM CONDITION
		6	20				AS Per MOD
		71	74				DUE TO SYSTEM CONDITION
14	KHAPERKHEDA-U 1 TO 4	1	7	653	569	84	DUE TO SYSTEM CONDITION
		8	20				AS Per MOD
		71	74	608	569	39	DUE TO SYSTEM CONDITION
15	PARAS-3	1	8	182	164	18	DUE TO SYSTEM CONDITION
		9	18				AS Per MOD
		71	72				DUE TO SYSTEM CONDITION
		73	74	X	X	X	DC REVISED TO BELOW TECHNICAL MINIMUM DUE TO PCQ
16	PARAS-4	1	9	182	168	14	DUE TO SYSTEM CONDITION
		10	18				AS Per MOD
		71	72				DUE TO SYSTEM CONDITION
		73	74	X	X	X	DC REVISED TO BELOW TECHNICAL MINIMUM DUE TO PCQ
17	KHAPERKHEDA-5	X	X	X	X	X	UNIT UNDER OUTAGE
18	JSW U 1	1	18	275	200	75	DUE TO SYSTEM CONDITION
19	AMNEPL TO REL	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
20	APML U 2,3 TO MSEDCL	3	8	617	550	67	DUE TO SYSTEM CONDITION
		37	84	617	432	185	DUE TO OUTAGE FOR BUS BAR TESTING AND COMMISSIONING WORK AT 400 KV WARORA

TPC U 8 , U 5 & REL G IN BLK(69-74) BACKING DOWN NOT IMPLEMENTED DUE TO LINE LOADING CONSTRAINT IN MUMBAI SYSTEM.

**Note :**

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- MOD rates revised w.e.f 12-Sep.-2013.