

| SR. NO. | GENERATING STN. / STOA | Backing Down Period (in Time Block) | | TARGET DESPATCHED SCHEDULE (in MW) | | Backing Down Quantum [Max] in MW [A-B] | REMARK |
|---------|------------------------|-------------------------------------|----|------------------------------------|-------------------------------|--|---|
| | | FROM | TO | Declared Capacity (A) | Despatched Schedule (Min) (B) | | |
| 1 | TPC U-6 | X | X | X | X | X | UNIT WITHDRAWN ON ECONOMIC SHUTDOWN |
| 2 | JSW MSEDCL FIRM | 1 | 60 | 200 | 140 | 60 | AS PER SYSTEM CONDITION |
| | | 79 | 96 | 200 | 140 | 60 | AS PER SYSTEM CONDITION |
| 3 | JSW TO RINFRA DA | 1 | 43 | 75 | 52.5 | X | NO SCHEDULE |
| | | 44 | 44 | 75 | 52.5 | 22.5 | AS PER SYSTEM CONDITION |
| | | 79 | 96 | X | X | X | SCHEDULE REVISED TO 45 MW |
| 4 | JSW MSEDCL FIRM | 1 | 60 | 70 | 49 | 21 | AS PER SYSTEM CONDITION |
| | | 79 | 96 | 70 | 49 | 21 | AS PER SYSTEM CONDITION |
| 5 | DHARIWAL TO MSEDCL | 1 | 60 | 150 | 140 | 10 | AS PER SYSTEM CONDITION |
| | | 79 | 96 | 150 | 140 | 10 | AS PER SYSTEM CONDITION |
| 6 | PARALI U-6 AND U-7 | X | X | X | X | X | UNIT-6 AND UNIT-7 W/DN FOR ZERO SCHEDULE BY MSEDCL |
| 7 | TPC U-5 | 1 | 22 | 473 | 292 | 181 | AS PER SYSTEM CONDITION |
| | | 29 | 43 | 473 | 292 | 181 | AS PER SYSTEM CONDITION |
| | | 79 | 96 | 473 | 292 | 181 | AS PER SYSTEM CONDITION |
| 8 | DTPS REL U1 AND U2 | 1 | 22 | 458 | 336 | 122 | AS PER SYSTEM CONDITION |
| | | 29 | 40 | 458 | 336 | 122 | AS PER SYSTEM CONDITION |
| | | 80 | 96 | 458 | 336 | 122 | AS PER SYSTEM CONDITION |
| 9 | TATA U-8 | 1 | 22 | 235 | 187 | 48 | SCHEDULE BELOW TECH MIN. |
| | | 35 | 40 | 235 | 187 | 48 | SCHEDULE BELOW TECH MIN. |
| | | 80 | 96 | 235 | 187 | 48 | AS PER SYSTEM CONDITION |
| 10 | NASHIK U-3,4,5 | 1 | 20 | 324 | 284 | 40 | UNIT-5 W/DN FOR ZERO SCHEDULE BY MSEDCL |
| | | 35 | 40 | 324 | 284 | 40 | UNIT-5 W/DN FOR ZERO SCHEDULE BY MSEDCL |
| | | 80 | 96 | 324 | 284 | 40 | UNIT-5 W/DN FOR ZERO SCHEDULE BY MSEDCL |
| 11 | BHUSWAL U-2 AND U-3 | X | X | X | X | X | UNIT-2 AND UNIT-3 SHUT DOWN |
| 12 | RATTANINDIA U1 TO U-5 | 1 | 20 | 490 | 344 | 146 | UNIT-3 & 5 SHUT DOWN AND UNIT-4 W/DN FOR ZERO SCHEDULE BY MSEDCL |
| | | 35 | 40 | 490 | 344 | 146 | UNIT-3 & 5 SHUT DOWN AND UNIT-4 W/DN FOR ZERO SCHEDULE BY MSEDCL |
| | | 81 | 96 | 490 | 344 | 146 | UNIT-3 & 5 SHUT DOWN AND UNIT-4 W/DN FOR ZERO SCHEDULE BY MSEDCL |
| 13 | PARLEY U-8 | 1 | 20 | 200 | 166 | 34 | AS PER SYSTEM CONDITION |
| | | 81 | 96 | 180 | 166 | 14 | AS PER SYSTEM CONDITION |
| 14 | BHUSWAL U-4 AND U-5 | 1 | 20 | 940 | 644 | 296 | AS PER SYSTEM CONDITION |
| | | 81 | 96 | 940 | 644 | 296 | AS PER SYSTEM CONDITION |
| 15 | KHAPERKHEDA U-1 TO U-4 | 1 | 20 | 300 | 289 | 11 | UNIT-3,4 SHUT DOWN; BD AS PER SYSTEM CONDITION |
| | | 81 | 96 | 433 | 424 | 9 | UNIT-4 SHUT DOWN; U-4 SYN AT 8:16 HRS. AND BD AS PER SYSTEM CONDITION |
| 16 | VIPL U-1 AND U-2 | 1 | 19 | 572 | 382 | 190 | AS PER SYSTEM CONDITION |
| | | 82 | 96 | 572 | 382 | 190 | AS PER SYSTEM CONDITION |

| SR. NO. | GENERATING STN. / STOA | Backing Down Period (in Time Block) | | TARGET DESPATCHED SCHEDULE (in MW) | | Backing Down Quantum [Max] in MW [A-B] | REMARK |
|---------|----------------------------|-------------------------------------|----|------------------------------------|-------------------------------|--|---|
| | | FROM | TO | Declared Capacity (A) | Despatched Schedule (Min) (B) | | |
| 17 | ADANI TIRODA 440 PPA | 1 | 19 | 215 | 0 | 215 | AS PER SYSTEM CONDITION |
| | | 82 | 96 | 215 | 0 | 215 | AS PER SYSTEM CONDITION |
| 18 | ADANI U- 1 (1200+125)MW PP | 1 | 19 | 441 | 432 | 9 | AS PER SYSTEM CONDITION |
| | | 82 | 96 | 441 | 432 | 9 | AS PER SYSTEM CONDITION |
| 21 | ADANI U-4 (1200+125)MW PP | 1 | 19 | 441 | 432 | 9 | AS PER SYSTEM CONDITION |
| | | 82 | 96 | 441 | 432 | 9 | AS PER SYSTEM CONDITION |
| 22 | ADANI U-5 (1200+125)MW PP | 1 | 19 | 441 | 432 | 9 | AS PER SYSTEM CONDITION |
| | | 91 | 96 | 441 | 432 | 9 | AS PER SYSTEM CONDITION |
| 23 | KHAPERKHEDA U-5 | 1 | 19 | 423 | 335 | 88 | AS PER SYSTEM CONDITION |
| | | 93 | 96 | 423 | 335 | 88 | AS PER SYSTEM CONDITION |
| 24 | CHANDRAPUR U-3 TO U-7 | 1 | 17 | 917 | 806 | 111 | UNIT-5 & 6 SHUT DOWN; U-3 WDN ON BTL AT 00:45 HRS. AND BD AS PER SYSTEM CONDITION |
| | | 93 | 96 | 1382 | 1134 | 248 | UNIT-5 & 6 SHUT DOWN; U-6 SYN AT 9:37 HRS. AND BD AS PER SYSTEM CONDITION |
| 25 | KORADI U-5,6,7 | 1 | 17 | X | X | X | UNIT- 5 ,6 SHUT DOWN; U-7 SYN AT 19:12 HRS. |
| 26 | PARAS U-3 AND U-4 | 1 | 17 | 460 | 332 | 128 | AS PER SYSTEM CONDITION |
| | | 93 | 96 | 460 | 332 | 128 | AS PER SYSTEM CONDITION |
| 27 | CHANDRAPUR U-8 AND U-9 | X | X | X | X | X | NO BACKDOWN; U-8 WDN AT 16:21 HRS. OF 24/10/17 |
| 28 | KORADI U-8,9,10 | X | X | X | X | X | NO BACKDOWN |
| 26 | JSW U-1 | X | X | X | X | X | NO BACKDOWN |
| 27 | ADANI U-3 | X | X | X | X | X | NO BACKDOWN |
| 28 | ADANI U-2 | X | X | X | X | X | UNIT SHUT DOWN |

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D. RATES REVISED FROM DT. 12TH OCT. 2017
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.