

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

25-Nov-12

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	27	483	145	338	AS Per MOD
		83	96				
		28	37	483	235	248	
		51	70	483	370	113	
		71	82	483	230	253	
2	TPC U-5	X	X	X	X	X	UNIT NOT ON BAR
		95	96	473	260	213	UNIT SYNC. ; B/D DUE TO SYSTEM CONDITION
3	JSW U4 TO MSEDCL	x	x	x	x	x	MSEDCL REQUIREMENT OF TECHNICAL MINIMUM
4	JSW U2 TO MSEDCL	x	x	x	x	x	MSEDCL REQUIREMENT OF TECHNICAL MINIMUM
5	NASIK	2	24	344	310	34	AS Per MOD
		90	96				DUE TO SYSTEM CONDITION
6	TPC U-8	1	23	235	180	55	AS Per MOD
		90	96				DUE TO SYSTEM CONDITION
7	BHUSAWAL-2,3	X	X	X	X	X	DC REVISED DUE TO PCQ ; LESS THAN TECH. MINIMUM
8	KORADI	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	PARALI U# 3,4,5	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
10	REL-G	5	21	479	336	143	AS Per MOD

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 11-Nov-2012.