

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCH SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (B)		
1	TPC U-6	X	X	X	X	X	UNIT WITHDRAWN ON ECONOMIC SHUTDOWN
2	JSW TO MSEB FIRM	1	45	200	140	60	AS PER SYSTEM CONDITION
		76	96	200	140	60	AS PER SYSTEM CONDITION
3	TPC U-5	1	27	473	292	181	AS PER SYSTEM CONDITION
		38	43	473	292	181	AS PER SYSTEM CONDITION
		77	96	473	292	181	AS PER SYSTEM CONDITION
4	TPC U-8	X	X	X	X	X	UNIT SHUT DOWN
5	DTPS REL U1 AND U2	1	26	460	336	124	AS PER SYSTEM CONDITION
		38	43	460	336	124	AS PER SYSTEM CONDITION
		77	96	460	336	124	AS PER SYSTEM CONDITION
6	NASHIK U-3,4,5	1	26	302	284	18	UNIT-5 SHUT DOWN, B/D AS PER SYSTEM CONDITION
		38	43	320	284	36	UNIT-5 SHUT DOWN, B/D AS PER SYSTEM CONDITION
		77	96	320	284	36	UNIT-5 SHUT DOWN, B/D AS PER SYSTEM CONDITION
7	BHUSWAL U-2 AND U-3	X	X	X	X	X	UNIT-2 AND UNIT-3 SHUT DOWN
8	RATTANINDIA U1 TO U-5	1	19	490	344	146	AS PER SYSTEM CONDITION UNIT-2 ,3, 5 SHUT DOWN
		38	43	490	344	146	AS PER SYSTEM CONDITION UNIT-2 ,3, 5 SHUT DOWN
		76	96	490	344	146	AS PER SYSTEM CONDITION UNIT-2 ,3, 5 SHUT DOWN
9	PARLEY U-6 AND U-7	1	19	200	166	34	AS PER SYSTEM CONDITION UNIT-7 SHUT DOWN
		38	43	249	186	63	AS PER SYSTEM CONDITION UNIT-7 Syn. 7:32hrs
		76	96	429	332	97	AS PER SYSTEM CONDITION UNIT-7 SHUT DOWN
10	BHUSWAL U-4 AND U-5	1	19	658	644	14	AS PER SYSTEM CONDITION
		38	43	658	644	14	AS PER SYSTEM CONDITION
		76	96	658	644	14	AS PER SYSTEM CONDITION
11	VIPL U-1 AND U-2	1	19	X	X	X	D.C. TECH MIN
		38	43	X	X	X	D.C. TECH MIN
		76	96	X	X	X	D.C. TECH MIN
12	PARALI U-8	X	X	X	X	X	UNIT SHUT DOWN
13	KHAPERKHEDA U-1 TO U-4	1	16	X	X	X	D.C. BELOW TECH MIN UNIT-1 AND UNIT-2, UNIT-3 SHUT DOWN,
		38	43	X	X	X	D.C. BELOW TECH MIN UNIT-1 AND UNIT-2, UNIT-3 SHUT DOWN,
		79	96	X	X	X	UNIT-4 TRIPPED 19:19HRS UNIT-1 AND UNIT-2, UNIT-3 SHUT DOWN,
14	PARAS U-3 AND U-4	1	16	460	332	128	AS PER SYSTEM CONDITION
		38	43	460	332	128	AS PER SYSTEM CONDITION
		81	96	460	332	128	AS PER SYSTEM CONDITION
15	ADANI TIRODA 440 PPA	1	16	127	0	127	AS PER SYSTEM CONDITION
		81	96	127	0	127	AS PER SYSTEM CONDITION
16	KORADI U-5,6,7	X	X	X	X	X	UNIT -5,6,7 SHUTDOWN
17	ADANI U-1 (1200+125)MW PP	1	16	550	432	118	AS PER SYSTEM CONDITION
		81	96	550	432	118	AS PER SYSTEM CONDITION
18	ADANI U-4 (1200+125)MW PP	1	16	550	432	118	AS PER SYSTEM CONDITION
		81	96	550	432	118	AS PER SYSTEM CONDITION
19	ADANI U-5 (1200+125)MW PP	X	X	X	X	X	UNIT SHUT DOWN
20	KHAPERKHEDA U-5	1	16	X	X	X	D.C. BELOW TECH. MIN
		93	96	423	335	88	AS PER SYSTEM CONDITION
21	CHANDRAPUR U-3 TO U-7	1	8	786	656	130	UNIT-3, UNIT-4 UNIT-5 AS PER SYSTEM CONDITION
		93	96	786	656	130	UNIT-3, UNIT-4 UNIT-5 AS PER SYSTEM CONDITION
22	KORADI U-8,9,10	1	8	1096	864	231	UNIT-8 SHUT DOWN,D.C. BELOW TECH MIN
		93	96	990	864	126	UNIT-8 SHUT DOWN,B/D AS PER SYSTEM CONDITION
23	JSW U-1	1	8	281	200	81	AS PER SYSTEM CONDITION
		93	96	281	200	81	AS PER SYSTEM CONDITION
24	CHANDRAPUR U-8 AND U-9	1	8	882	656	224	AS PER SYSTEM CONDITION
		93	96	882	656	224	AS PER SYSTEM CONDITION
25	IEPL TO MSECL DA	X	X	X	X	X	UNIT SHUT DOWN
26	ADANI U-3	X	X	X	X	X	UNIT SHUT DOWN
27	ADANI U-2	1	7	623	432	191	AS PER SYSTEM CONDITION
		94	96	623	660	63	AS PER SYSTEM CONDITION

Note :

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- M.O.D. RATES REVISED FROM DT. 12TH NOV 2016
- # Indicates that back down withdrawn due to Line loading/system constraints.