

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	38	516	425	91	AS PER MOD
		65	76				
		78	96				
3	PARALI 3,4,5	1	32	302	276	26	AS PER MOD
		69	74				
		81	96				
4	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
5	PARALI-7	1	32	180	166	14	AS PER MOD
		70	72				
		81	96				
6	JSW U 2,4 TO BEST(100 MW) SCH.GIVEN FROM BLK(41-76)	70	72	96.5	67.5	29	AS PER MOD
7	PARALI-6	1	32	180	166	14	AS PER MOD
		70	72				
		81	96				
8	JSW U 3,4 TO RINFRA DA (JSWPTC) VARIABLE SCH.GIVEN FROM BLK(36-52 & 73-84))	82	82	50	35	15	AS PER MOD
9	BHUSAWAL-4	1	32	330	322	8	DUE TO SYSTEM CONDITION
		70	72				
		81	96				
10	TPC U-5	1	32	473	292	181	AS PER MOD
		70	72	473	385	88	
		82	96	473	292	181	
11	TPC U-8	1	27	235	172	63	AS PER MOD
		28	32				DUE TO SYSTEM CONDITION
		82	96				AS PER MOD
12	KORADI 5,6,7	1	27	306	299	7	AS PER MOD
		28	32				DUE TO SYSTEM CONDITION
		87	96	X	X	X	DC REVISED TO BELOW TECHNICAL MINIMUM DUE TO PCQ
13	REL G	1	26	478	336	142	AS PER MOD
		27	32				DUE TO SYSTEM CONDITION
		87	96				AS PER MOD
14	KHAPER KHEDA U 1 TO 4	1	24	653	569	84	AS PER MOD
		25	32				DUE TO SYSTEM CONDITION
		88	96				AS PER MOD
15	KHAPERKHEDA-U5	1	21	475	335	140	AS PER MOD
		22	32				DUE TO SYSTEM CONDITION
		88	96				AS PER MOD
16	CHANDRAPUR	1	3	1249	1082	167	DUE TO SYSTEM CONDITION
		4	21				AS PER MOD
		89	96	1194	1068	126	
17	INDIABULL TO MSEDCL	1	3	245	172	73	DUE TO SYSTEM CONDITION
		4	19				AS PER MOD
		89	92				
		93	96				DUE TO SYSTEM CONDITION
18	PARAS -U3	1	6	191	164	27	DUE TO SYSTEM CONDITION
		7	19				AS PER MOD
		90	92				
		93	96				DUE TO SYSTEM CONDITION
19	PARAS U4	1	6	210	168	42	DUE TO SYSTEM CONDITION
		7	19				AS PER MOD
		90	96				DUE TO SYSTEM CONDITION
20	APML U-1	1	18	605	432	173	DUE TO SYSTEM CONDITION
		94	96	605	500	105	
21	JSW U-1	1	17	275	200	75	DUE TO SYSTEM CONDITION
22	APML U-2,3	1	17	623	432	191	DUE TO SYSTEM CONDITION

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-Dec.-2013.