PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:

26/04/2019

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)			
		FROM	то	Declared Capacity <i>(A)</i>	Despatched Schedule (Min) <i>(B)</i>	Backing Down Quantum [Max] in MW <i>[A-B]</i>	REMARK
1	JSW U-2 3 AND 4 TO MSEDCL	1	23	200	140	60	AS PER SYSTEM CONDITION
		28	96	200	140	60	AS PER SYSTEM CONDITION
2	DHARIWAL TO MSEDCL	1	23	205	143.5	61.5	AS PER SYSTEM CONDITION
		28	96	205	143.5	61.5	AS PER SYSTEM CONDITION
3	JSW TO AEML (DA)	1	23	120	84	96	AS PER SYSTEM CONDITION
		28	96	120	84	96	AS PER SYSTEM CONDITION
4	TPC U-8	73	76	227	172	32	AS PER SYSTEM CONDITION
5	DTPS U-1 & U-2	73	76	428	336	92	AS PER SYSTEM CONDITION
6	VIPL U-1 & U-2	x	x	x	x	x	UNIT OUT DUE TO COAL SHORTAGE
7	TPC U-5	73	76	473	292	181	AS PER SYSTEM CONDITION
8	PARALI U-6 & U-7	x	x	x	x	x	ZERO SCHEDULE BY MSEDCL
9	BHUSAWAL U-3	x	x	x	x	x	ZERO SCHEDULE BY MSEDCL
10	NASHIK U-3, U-4 & U-5	x	x	x	x	x	NO BACK DOWN
11	RATTANINDIA U-1 TO U-5	x	x	x	x	x	NO BACK DOWN
12	PARALI U-8	x	x	x	x	x	NO BACK DOWN
13	KORADI U-6 & U-7	x	x	x	x	x	NO BACK DOWN
14	KORADI U-8 TO U-10	x	x	x	x	x	NO BACK DOWN
15	BHUSAWAL U-4 & U-5	x	x	x	x	x	NO BACK DOWN
16	JSW U-1	x	x	x	x	x	NO BACK DOWN
17	CHANDRAPUR U-3 TO U-7	x	x	x	x	x	NO BACK DOWN
18	ADANI U-1, U-4 & U-5 (PPA 440 MW)	x	x	x	x	х	NO BACK DOWN
19	ADANI TIRODA U-1(PPA 1200MW(&125MW)	x	x	х	x	х	NO BACK DOWN
20	CHANDRAPUR U-8 & U-9	x	x	х	x	х	NO BACK DOWN
21	PARAS U-3 & U-4	x	x	x	x	х	NO BACK DOWN
22	KHAPERKHEDA U-1 TO U-4	x	x	х	x	х	NO BACK DOWN
23	KHAPERKHEDA U-5	x	x	x	x	х	NO BACK DOWN
24	ADANI U-2 & 3	x	x	x	x	х	NO BACK DOWN

Note :

1

Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM DT. 16TH APRIL- 2019

3 # Indicates that back down withdrawn due to Line loading/system constraints.