

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-5	28	34	470	260	210	AS PER SYSTEM CONDITION #
		81	96	470	260	210	AS PER SYSTEM CONDITION #
2	TPC U-8	28	34	229	126	103	AS PER SYSTEM CONDITION #
		81	96	229	126	103	AS PER SYSTEM CONDITION #
3	DTPS U-1 & U-2	28	33	455	250	205	AS PER SYSTEM CONDITION #
		81	96	455	250	205	AS PER SYSTEM CONDITION #
4	NASIK U-3, U-4 & U-5	71	96	362	204	158	AS PER SYSTEM CONDITION/ U-3 UNDER CASE IV
5	KORADI U-6 & U-7	71	96	261	206	55	AS PER SYSTEM CONDITION
6	SWPGL to MSEDCL	71	93	154	132	22	AS PER SYSTEM CONDITION/ U-2 OUT
7	BHUSAWAL U-3	72	93	174	104	70	AS PER SYSTEM CONDITION
8	PARALI U-6 & U-7	72	93	360	242	118	AS PER SYSTEM CONDITION
9	PARALI U-8	72	93	180	122	58	AS PER SYSTEM CONDITION
10	DHARIWAL to MSEDCL (Case-IV)	72	78	185	101.75	83.25	AS PER SYSTEM CONDITION
		83	91	185	101.75	83.25	AS PER SYSTEM CONDITION
11	APML U-1, U-4 & U-5 (PPA440 MW)	73	78	440	0	440	AS PER SYSTEM CONDITION
		83	90	440	0	440	AS PER SYSTEM CONDITION
12	APML U-1, U-4 & U-5 (PPA 125 MW)	75	78	125	96	29	AS PER SYSTEM CONDITION
		83	90	125	96	29	AS PER SYSTEM CONDITION
13	APML U-1, U-4 & U-5 (PPA 1200 MW)	75	78	1200	921	279	AS PER SYSTEM CONDITION
		83	90	1200	921	279	AS PER SYSTEM CONDITION
14	RATTANINDIA U-1 TO U-5	76	78	735	405	330	AS PER SYSTEM CONDITION/ U-1&2 OUT
		84	89	735	405	330	AS PER SYSTEM CONDITION/ U-1&2 OUT
15	BHUSAWAL U-4 & U-5	76	78	920	518	402	AS PER SYSTEM CONDITION
		84	89	920	518	402	AS PER SYSTEM CONDITION
16	KHAPERKHEDA U-1 TO U-4	76	78	426	311	115	AS PER SYSTEM CONDITION/ U-2 OUT
		86	89	426	311	115	AS PER SYSTEM CONDITION/ U-2 OUT
17	CHANDRAPUR U-3 TO U-7	76	78	903	607	296	AS PER SYSTEM CONDITION/ U-4&7 OUT
		86	88	903	607	296	AS PER SYSTEM CONDITION/ U-4&7 OUT
18	PARAS U-3 & U-4	X	X	X	X	X	NO BACK DOWN
19	KORADI U-8 TO U-10	X	X	X	X	X	NO BACK DOWN
20	CHANDRAPUR U-8 & U-9	X	X	X	X	X	NO BACK DOWN
21	KHAPERKHEDA U-5	X	X	X	X	X	NO BACK DOWN
22	APML U-2 & U-3	X	X	X	X	X	NO BACK DOWN
23	SWPGL to BEST	X	X	X	X	X	NO BACK DOWN
24	JSW U-1	X	X	X	X	X	UNIT OUT

Note :

- MoD stack is prepared as per the clause 33 & 34 of MERC(State Grid Code) 2020.
- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations with ramp are available under "View Schedules" on website.
- # Indicates that back down withdrawn due to Line loading/system constraints.
- * Indicates that back down implemented due to Line loading/system constraints.
- Revised MOD Rates effective from 00:00 hrs of 16th Apr 2021