

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

26-May-12

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	1	32	483	145	338	AS Per MOD
		33	64	483	170	313	
		65	77	483	145	338	
		78	96	483	200	283	
2	AMNEPL-MSEDCL (STOA)	x	x	x	x	x	MSEDCL HAS CURTAILED POWER FROM 50 TO 35MW (00:00 TO 24:00 HRS)
3	WPCL-MSEDCL (STOA)	x	x	x	x	x	MSEDCL HAS CURTAILED POWER FROM 50 TO 35MW (06:00 TO 22:00 HRS)
4	JSW U-4	x	x	x	x	x	MSEDCL HAS CURTAILED POWER FROM 00:00 to 24:00 hrs to 192 MW (TECHNICAL MINIMUM)
5	TPC U-5	2	32	473	260	213	AS Per MOD
		68	77	473	350	123	

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-MAY-2012.