

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

26-May-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	96	483	145	338	AS PER MOD
2	NASIK	1	96	511	425	86	AS PER MOD
3	BHUSAWAL 2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
4	JSW U-2,4-MSEDCL	5	96	250	175	75	AS PER MOD
5	VIPL TO MSEDCL	7	79	85	59.5	25.5	AS PER MOD
		81	92				
		96	96	85	79	6	
6	REL G	7	9	478	405	73	AS PER MOD
		12	88	475	336	139	
		89	96	475	336	139	DUE TO SYSTEM CONDITION
7	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	TPC U-5	13	20	473	430	43	AS PER MOD
		25	34	473	390	83	
		65	82	473	292	181	
9	TPC U-8	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
10	BHUSAWAL 4	72	76	X	X	X	DC REVISED DUE TO PCQ
		77	78	400	332	68	DUE TO SYSTEM CONDITION
11	K'KHEDA U-1,2,3,4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
12	CHANDRAPUR	72	78	1808	1676	132	DUE TO SYSTEM CONDITION

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f. 12-May-2013.