

STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE: <u>26-May-14</u>							
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	x	x	x	x	x	SCHEDULE TECH MIN
2	PARALI-3,4,5	10	23	292	276	16	DUE TO SYSTEM CONDITION
		41	43	292	280	12	AS PER MOD
		70	74	292	276	16	
3	NASIK	10	23	344	284	60	DUE TO SYSTEM CONDITION
		70	74	344	284	60	AS PER MOD
4	KORADI	x	x	x	x	x	DECL TECH MIN
5	BHUSAWAL-2,3	x	x	x	x	x	DECL TECH MIN
6	VIPL TO RINFRA U-1	13	20	210	190	20	AS PER MOD
		72	73	210	190	20	
7	VIPL TO RINFRA U-2	13	20	210	190	20	DUE TO SYSTEM CONDITION
		73		210	192	18	AS PER MOD
8	JSW TO RINFRA 100 MW	13	20	50	35	15	AS PER MOD
9	DHARIWAL TO TPCD (100 MW)	x	x	x	x	x	AS PER MOD
10	TPC U-8	x	x	x	x	x	NO SCHEDULE
11	TPC U-5	15	20	473	380	93	DUE TO SYSTEM CONDITION
12	DHARIWAL TO TPCD (150 MW)	x	x	x	x	x	DECL TECH MIN DURING BACK DOWN PERIOD
13	JSW TO MSEDCL (285 MW)	16	20	285	185	100	DUE TO SYSTEM CONDITION
14	PARLY U-6	x	x	x	x	x	DECL BELOW TECH MIN
15	PARLY U-7	x	x	x	x	x	DECL BELOW TECH MIN
16	BHUSAWAL U4	x	x	x	x	x	DECL BELOW TECH MIN
17	REL GEN	16	20	473	336	137	DUE TO SYSTEM CONDITION
18	BHUSAWAL U-5	x	x	x	x	x	DECL BELOW TECH MIN
19	KHAPER KHEDA U 5	x	x	x	x	x	DECL BELOW TECH MIN
20	KHAPER KHEDA U 1 TO 4	x	x	x	x	x	DECL BELOW TECH MIN
21	CHANDRAPUR	16	20	1657	1495	162	DUE TO SYSTEM CONDITION
22	INDIA BULL U1	16	20	245	172	73	DUE TO SYSTEM CONDITION
23	INDIA BULL U2	x	x	x	x	x	UNIT SHUTDOWN
24	PARAS -U3	16	20	191	164	27	DUE TO SYSTEM CONDITION
25	PARAS U4	16	20	230	168	62	DUE TO SYSTEM CONDITION

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 MOD rates revised w.e.f 12-May-2014.